



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001



484

No. F.6/DFS/MS/SZ/GH/2025/23

Dated: 07/01/2026

To,

Mr. Arun Kuamr Jain,
House No.6B, Street No.10,
Old Rajender Nagar,
Delhi-110060.

Sub: Renewal of FSC in r/o M/s Bonlon Inn (Bonlon Industries Limited) located at 7A, Street No.39, WEA Karol Bagh, New Delhi-110005.

Sir,

This is in reference to online application no. 2025120515434 dated 05.12.2025, received in this department on the subject cited above. In this connection it is to inform you that the building premises has been visited by the officers concerned of this department on 27.12.2025 presence of Mr. Brijesh (Manager) and observed that the shortcoming already issued by this department letter of even No. 258 dated 26.05.2025 are not yet rectified and during the inspection, some shortcomings has been found. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Shortcoming already conveyed are not yet rectified.
2. First Aid hose reel is provided but not functional.
3. Carbon monoxide detector is provided but not functional.
4. Terrace Fire pump with capacity of 450 LPM provided but not functional.
5. The required exit sign are found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


6/1/26

(A. K. MALIK)
Dy. Chief Fire Officer
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2025120515434 dated 05.12.2025.

