



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**



C-174

No. F.6/DFS/MS/CN/BNQT./2026/ 889

Dated: 22/09/2026

To,

The Commissioner,  
MCD, Civic Centre, Minto Road,  
New Delhi-110002.

**Sub:** Renewal of FSC in r/o M/s Bonlon The Legend (A unit of Delicious Coco Water Pvt. Ltd.) located at D-13, Gr. 1st & 2nd floor, Udyog Nagar Industrial Area, Udyog Nagar, Delhi-110041.

Sir,

This has reference to online application no. 2026080310264 dated 04.08.2026 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 20.08.2026, in presence of Mr. Chauhan to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire Check Door (FCD) found removed at some places and some fire check doors needs to be repaired.
2. Smoke management system in basement found removed.
3. Detector found removed at some places.
4. MOEFA found provided but not functional.
5. Entire pumping system not found in auto mode.
6. Exit signage's found removed at some places.
7. Electrical panel inside the staircase needs to be either removed or segregated with a fire check door.
8. Temporary structure at terrace floor found used as kitchen has to be removed/dismantled.

In this regard as stipulated in sub-Rule 37 of Delhi Fire Service (Amendment) Rules, 2025 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(A. K. MALIK)  
Chief Fire Officer  
Delhi Fire Service

Copy to :-

1. MCD Portal ID-2026080310264 dated 04.08.2026.

du  
24