

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/ 135
To

Dated 28/01/2025

Mr. Ritesh Jain,
Plot No D-14, Pushpanjali Enclave,
Pitampura Delhi 110034.

Sub: - Regarding issuance of FSC in r/o M/s Bouncing Pouncing at Okhla NSIC Metro Station, Delhi 110018.

Sir,

This has reference to with letter no nil dated 13/01/2025 received through outdoor diary no 11512 dated 17/01/2025 on the subject cited above. In this connection, this is to inform you that requisite reply has already been furnished vide this department letter of even no F6/DFS/MS/2025/SZ/30 dated 20/01/2025 is enclosed for your ready reference.

This is for your information and action at your end.

Yours faithfully

(ATUL GARG)
DIRECTOR)

DELHI FIRE SERVICE

Atul Garg

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2025/SZ/30
To

Dated: 20/01/2025

The Joint Commissioner of Police, Lic/Branch,
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Bouncing Pouncing located at Ground floor of Okhla NSIC Metro Station of Line 8 (Janak Puri West to Kalindi Kunj Section) New Delhi

Sir,

This has reference to your letter no 01/Joint CP/Lic. (Amst) dated 02/01/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14/01/2025 in the presence of Ms. Nisha to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are three exit doors available in the game zone. Out of there three, one door having width of 2 mtr is open & two doors found closed.
2. Exit signage's not provided at some places.
3. The eating house is running inside the gaming zone area, which may cause to a fire. The eating house needs to be segregated from the gaming zone area.
4. Inflammable material (Plastic & PVC Sheets for decorative material) is being used for wall paneling/ ceiling level, which is not acceptable as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy To-

1. Sh. Ritesh Jain Prop. No D-14, Pushpanjali, Pitam Pura, Delhi