



No. F6/DFS/MS/School/NDZ/2025/231

Dated: 17/04/2025

To,

The Principal,  
B.S.P. Modern Public School  
B – 140 - A, Bhagirathi Vihar,  
Near Shiv Mandir, Delhi – 110094

**Subject: - Regarding grant of Fire Safety Certificate in r/o B.S.P. Modern Public School located at B – 140 - A, Bhagirathi Vihar, Near Shiv Mandir, Delhi – 110094.**

Sir,

This has a reference to your Outdoor diary no. 12537 dated 17/02/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/03/2025 in the presence of Mrs. Rozi Pal (Principal) and observed that building comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. One staircase of width 0.92 meter is provided in building instead of required 02 nos. of staircase of width 1.50 meter each.
2. Width of corridor 1.20 meter provided against requirement of 1.50 meter.
3. Door size of 0.85 meter provided against requirement of 1.20 meter.
4. First-Aid-Hose Reel not provided.
5. Terrace level fire pump capacity of 450 LPM not provided.
6. Overhead tank of capacity 10,000 liters not provided.
7. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

OK (w) DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.