



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



C-28

No. F6/DFS/MS/EH/WZ/2026/182

Dated:- 03/03/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Burger King (A Unit of Holy Shrine Hotels Pvt. Ltd.), located at Property No. 38-UA, Ground Floor, Jawahar Nagar, Bunglow Road, Delhi-110007, in the building comprised of ground, mezzanine & 02 upper floors but restaurant is running at ground floor only, owned/occupied by M/s Burger King (A Unit of Holy Shrine Hotels Pvt. Ltd.), was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2023/EH/314 dated 26/10/2023. The said premise was re-inspected by the officer concerned of this department on 23/02/2026 in the presence of Sh. K.K. Jain (Manager B.D.) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D "Assembly Building" (Restaurant) for ground floor only with effect from 03/03/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 03/03/2026 at New Delhi by.

S.K. Dua
02/03/26

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Q. O. C.
02/03/26

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002 :- in r/o online application id. 2026020301209 dated 03/02/2026.
2. The Authorized Signatory, M/s Burger King (A Unit of Holy Shrine Hotels Pvt. Ltd.), Property No. 38-UA, Ground Floor, Jawahar Nagar, Bunglow Road, Delhi-110007.

Conditions for the validity of fire safety certificate :-

1. This FSC is valid only for restaurant at ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

N/8
INSPECTION REPORT

1. Name & address of the building : M/s Burger King (A Unit of Holy Shrine Hotels Pvt. Ltd.) located at 38-UA, Jawahar Nagar, Bunglow Road, Delhi-110007
2. Type of Occupancy : Assembly (Restaurant)
3. Composition of building : Ground, Mezzanine & 02 Upper Floors, but **restaurant is running at ground floor only**, mezz. floor-store, 1st floor-saloon & 2nd floor-academy
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2023/EH/314 dated 26/10/2023
6. Fire Safety directives Letter No. : Nil
7. Date of inspection : 23/02/2025
8. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
9. Name and designation of Officer from the building side : Sh. K.K. Jain (Manager B.D.)
10. Year of Construction : 2002
11. Applicant's letter no. : 2026020301209 dated 03/02/2026

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per NBC/UBBL		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	06 m	12 m approx.		MR
	• Gate width	NA	NA		NA
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	NA	NA		NA
	• Basements	NA	NA		NA
	b. Width of staircases				
	• Upper floors	NA	NA		NA
	• Basements	NA	NA		NA
	c. Protection of exits				
	• Fire check door	NA	NA		NA
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	NA	NA		NA
	e. Width Of Corridor	NA	NA		NA
	f. Door Size	2.0 m & 1.5 m	2.0 m & 1.5 m		MR
3.	Compartmentation				
	• Fire check door	NA	NA		NA
	• Sealing of electrical shafts	NA	NA		NA
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	NA	NA		NA
	• Upper floors	Required	Provided		MR
5.	Fire Extinguishers				
	• Total numbers	04 nos.	04 nos.		MR
	• Types	ABC & CO ₂	Provided		MR
	• IS marking	ISI Marked	Provided		MR

P. J

6.	First - Aid Hose Reels			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose Box	01 no.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm x 2	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

R. S.

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/2023/EH/314 dated 26/10/2023 renewal under rule 37 of the Delhi Fire Service Rule 2010 is **recommended**.

Accordingly DFA is prepared & put up for approval please.

~~DO (110)~~
~~ADG~~
 27/02/2026

[Signature]
 27/02/26
 Aman Kumar Lathar
 ADO (BW/RN)

~~Sy CFO (CO2)~~

[Signature]
 27/02/26

~~Pr. Director~~

My. CFO to Secy.
[Signature]
 27/02/26

My. CFO (WZ)

F.P. letter is put-up for your signature Mr.

~~DO (110)~~

[Signature]
 02/03/26

[Signature]
 02/03/26
 ADO (BW/RN)

F.P. wing

Updated
 03/03/26
[Signature]