



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/EH/SZ/2026/27

Dated: 23/11/2026

To

The Commissioner,  
Municipal Corporation of Delhi,  
9<sup>th</sup> floor, Civic Centre, Minto Road,  
New Delhi-110002

Ref: etl.mcdonline application no. 2025112415084.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Burger King (A Unit of Restaurant Brands Asia Ltd) located at Unit No. 1, Paid Area, Inside Pink Line Metro Station Lajpat Nagar, New Delhi.

Sir,


In context to the application mentioned above, it is informed that the said Eating House/Restaurant is operating in Paid Area at Concourse level of Underground Lajpat Nagar Metro Station (Line-7).

The proposal/plans for any such Eating House has not been approved by this department and this is a addition/alternation in the preapproved plan of this Metro Station which may effect means of escape.

Delhi Metro Rail Corporation Ltd. (DMRC) may be requested to submit the revised plan for revision of the Fire Safety Directives.

In view of above, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
23/11/26  
(A.K. Malik)

Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

o/c DL  
21/11/26

Copy to –

1. The JGM/E&M, DMRC Ltd., Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-01.
2. The Manager, M/s Burger King (A Unit of Restaurant Brands Asia Ltd) located at Unit No. 1, Paid Area, Inside Pink Line Metro Station Lajpat Nagar, New Delhi.