



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/Mixed/SZ/2025/ 74

Dated: 13/02/2025

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: -Regarding renewal of Fire Safety Certificate in r/o M/s Cafeteria Co. (A Unit of Jumbo Restaurant Pvt. Ltd.) located at G - 14, 1st, 2nd, & 3rd floor, Vijay Nagar, Delhi.

Sir,

With reference to the etlmcsonline application ID no. 2025012100801 on the subject cited above, it is informed that the said premises was inspected by officer concerned of this department on 07.02.2025 in the presence of Mr. Sandeep Yadav (Manager) and following shortcomings were observed at the time of inspection.

1. Fire Check Door (FCD) found removed at 3rd floor kitchen.
2. All water based systems like Hose reel & Downcomer found non functional.
3. Fire pumps were found removed.
4. Underground tank found sealed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

11/2/2025