

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**


No.F6/DFS/MS/2026/SZ/ School/ 40

Dated: 25/03/2026

**FIRE SAFETY CERTIFICATE**

Certified that the Cambridge Primary School at A Block, New Friends Colony, New Delhi-25. comprised of Basement + Ground + 03 Upper floor & Auditorium at ground floor. The FSC was earlier granted by this department vide letter No. F6/DFS/MS/School/SZ/2023/427 dated 20.06.2023 for basement, ground and two upper floor. Now, premises was jointly inspected by the officers concerned of this department on 17-03-2026 in the presence of Mr. K.K. Varshney (AE) & Mr. Rahul Negi (JE) from MCD and found that the said premises has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group B "Educational Building" Sub-Div. B-I** with effect from .....25/03/2026 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on .....25/03/2026... at New Delhi by.

  
24/3/26  
(A. K. Malik)  
Dy. Chief Fire Officer

Copy to:-

1. The Commissioner , MCD , Civic Centre , New Delhi ID 10107276 dated 12.03.2026 : to kindly ensure the occupancy and deviation in construction if any.
2. Director of Education, Govt. of NCT, Delhi.
3. The Principal, Cambridge School at A Block, New Friends Colony, New Delhi-25.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any. Basement shall be used as per UBBL concerned.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building:- Cambridge School at A Block, New Friends Colony, New Delhi-25.
2. Type of occupancy:- Educational Group -B+ Gr.+03 Upper Floor & auditorium at ground floor.
3. Type of case:- Addition/alteration
4. Details of previous FSC:- F6/DFS/MS/School/SZ/2023/427 dated 20.06.2023 ( B+G+2 upper floor ) .
5. Fire safety directives No.- F6/DFS/MS/BP/2022/434 adted 18.10.2022
6. Date of inspection:- 17/03/26
7. Name of the inspecting officer:- Sh. Ravinder Singh (DO/SD) & Sh. Yashwant Singh Meena (ADO/MRD)
8. Name & designation of officer From the building side:- Mr. K.K. Varshney (AE) & Mr. Rahul Negi (JE) from MCD
9. Year of construction:- 2002 & 2026
10. Applicant's letter No:- online id no. 10107276 dated 12.03.2026 .

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NM R
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	5.0 mtrs	5.0 mtrs	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04	04	MR
	2. Basements	03 Nos. ( 02 in one basement & 1 in other basement)	03 Nos. ( 02 in one basement & 1 in other basement)	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtrs	2.0 mtrs, 1.5 mtrs., 1.5 mtrs., 1.63 mtrs.	MR
	2. Basements	1.5 mtrs	(1.8 mtrs, & 1.5 mtrs), 1.5 mtrs.	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	03	MR
	E. Width of corridor	1.5 mtrs	2.0 mtrs	MR
	F. Door size	1/1.20 mtr for class room	Provided	MR
		2.0 mtrs auditorium	Auditorium 6 nos. of 2.1 mtrs, 1 no. of 1.4 mtrs & (2.30 +1.12 +1.13)	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Mechanical/natural	Exhaust Fans	MR
	2) Upper floors	Mechanical/natural	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	22 Nos.	24Nos.	
	2) Types	ABC, Co2 & W.Co2	ABC, Co2 & W.Co2	MR
	3) ISI marking	Required	Provided	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	04 nos.	04 nos.	MR
	2) Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	100 mm	N/A
	2) Number of hydrants per floor	N/A	04 nos.	N/A
	3) Hose box	N/A	04 nos.	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	04 nos.	N/A
	2) Hose box	N/A	04 nos.	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450+450 LPM	900 + 1620 LPM	MR
	b) Head of pump	40 Mtrs	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	50,000 ltrs	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	15,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A


	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	N/A
18.	Refuge Area	N/A	N/A	MR
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.


In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. Hence, if approved, the FSC is recommended under Rule 35 of the Delhi Fire Service Rules 2010, Accordingly, DFA is put up for kind perusal/approval and signature please.

Last date 25/3/26

Signature of the Inspecting Officer

  
Name :- Ravinder Singh  
Designation :- D.O. (SD)

Signature of the Inspecting Officer

  
Name :- Yashwant Singh Meena  
Designation :- A. D.O. (MRD)

~~~~

  
23/3/26  
A.K. MALIK

~~Principal/Inchm~~

my. c/o to Jsmc.  
  
23/3/26

~~my. c/o (S2)~~

  
24/3/26  
A.K. MALIK

~~DO(SD)~~ AS approved, PFI put up for  
Kind perusal and sig. PFI.

~~~~  
  
24/3/26  
A.K. MALIK

  
24/3/26