



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2026/WZ/BNQT./ 162

Dated: 20/02/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Celebration Banquet located at A-16/3, Wazirpur Industrial Area, Delhi-110052, in the building comprised of Basement + Ground + 02 upper floors and Banquet Hall is running at ground + 01 upper floor only has already been issued FSC by this department vide letter No. F6/DFS/MS/WZ/BNQT./2023/08 dated 16.02.2023. The premises was re-inspected by the teams of officer concerned of this department on 11.02.2026 in the presence of Mr. Rajiv Nagpal and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Assembly - Group for Ground and First floor only with effect from 20/02/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/02/2026 at New Delhi by

Riv P
20/02/26
(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: Online MCD Portal ID-2026020201165 dated 02.02.2026.
2. The Manager, Celebration Banquet located at A-16 3, Ground floor, Wazirpur Industrial Area, Delhi-110052.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/> <http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

INSPECTION REPORT

1. Name & address of the building	M/s Celebration Banquet located at A-16 3, Ground floor, Wazirpur Industrial Area, Delhi-110052.			
2. Type of Occupancy	Assembly			
3. Comprised of building	Basement + Ground + 02 upper floors			
4. Type of Case	Renewal (Banquet Hall is running at ground + 01 upper floor)			
5. Details of Previous NOC	F6/DFS/MS/WZ/BNQT./2023/08 dated 16.02.2023			
6. Fire Safety directives letter No	F.6/DFS/MS/BP/2011/43 dated 06.01.2012.			
7. Date of inspection	11.02.2026			
8. Name of Inspecting Officer	Sh. Rajesh Kumar, DO (W), Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)			
9. Name and designation of officers From the building side	Mr. Rajiv Nagpal			
10. Year of Construction	2000 on MCD Portal			
11. Applicant's letter No.	Online application No.2026020201165 dated 02.02.2026.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35(6) of DFS Rules-2010	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	06m	Provided	MR
	• Gate width	05m	Provided	-NA-
	• Width of internal road	-NA-	-NA-	
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	03nos.	Provided	MR
	• Basements	02nos.	Provided	
	b. Width of staircases			MR(Old case)
	• Upper Floor	2 x 1.5 & 1.10m	1.75m, 1.5m & 1.0m	MR(Old case)
	• Basements	1.65m & 1m	1.6m & 0.90m	
	c. Protection of exits			MR
	• Fire check door	Required in basement	Provided	
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	2m	GF-2m & 1m FF-1.85m, 1m & 0.90m	MR
3.	Compartmentation	Required	Provided	MR
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	Required	Provided	MR
	b) Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	a) Total numbers	10nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	02nos.	Provided	MR

2

	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	Smoke/heat	Provided	MR
	b) Location of Main Panel	Required	Provided	MR
	c) Location of Repeater Panel	Required	Provided	MR
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA			
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
		-NA-	-NA-	-NA-
	a) Basement	Required	Provided	MR
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	02nos.	Provided	MR
	c) Hose Box	02nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	900lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity			
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity			
		20,000ltr	Provided	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	Required	Provided	MR
	d) Fireman's Grounding Switch	Required	Provided	MR

24

e) Lift S
Standby In
18. Ref.

21143

MR
MR

e) Lift Signage			
Standby power supply	Required	Provided	MR
18. Refuge Area.			
	Required	Provided	MR
a) Total Area			
b) Location	-NA-	-NA-	-NA-
19. Fire Control Room			
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:			
	Required	Provided	MR

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/WZ/BNQT./2023/08 dated 16.02.2023 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Office

Signature of the Inspecting Officer

Name: - Rajesh Kumar
Designation:- DO/W

Name: - Ajay Kumar Sharma
Designation:- ADO (WP/MN)

~~De. Officer~~

~~KVP~~
16/02/26

~~Pr. Director.~~

~~18/2/26~~

my. Cfo to JSSM.

~~my. Cfo (WP)~~

F.T. please.

~~KVP~~

~~ADO (WP)~~

FT letter is put up for kind perusal and signature please.

~~18/2/26~~

~~De. Officer~~

~~KVP~~
20/02/26

~~F.P. wing~~

~~23/2/26~~