

9/117

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/NDZ/2026/ 36

Dated : 11/03/2026

FIRE SAFETY CERTIFICATE

Certified that the **Centenary Hostel for Working Women, YMCA of Delhi**, located at **Ashoka Road, New Delhi - 110001** building comprised of Basement, Ground and 03 Upper Floors was issued FSC vide letter No. F6/DFS/MS/NDZ/2023/127 dated 02.03.2023. Now, the said premises was inspected by the officers concerned of this department on **24/02/2026** in the presence of **Sh. Charan Singh, Sh. Nikhil & Ms. Priya** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy "**Residential Building: Group - A** with effect from **11/03/2026** for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued ... 11/03/2026 ... at New Delhi by.



(Dr. S. K. Tomar)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The President, Centenary Hostel for Working Women, YMCA of Delhi, Ashoka Road, New Delhi - 110001.
2. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi - 110001 for online application ID: - 2025100313927 dated 12.02.2026.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building: -	Centenary Hostel for Working Women, YMCA of Delhi, Ashoka Road, New Delhi - 110001.		
2.	Type of occupancy: -	Residential Building, "Group-A"		
3.	Building Comprised of: -	Basement + Ground Floor + 03 Upper Floors		
4.	Type of case: -	Renewal		
5.	Details of previous FSC No.: -	F6/DFS/MS/NDZ/2023/127 dated 02.03.2023		
6.	Fire safety directives No.: -	N/A		
7.	Date of inspection: -	24/02/2026		
8.	Name of the inspecting officer: -	Sh. Manish Kumar, DO (CD) Sh. Bhupender Prakash, ADO (CC)		
9.	Name & designation of officer From the building side: -	Sh. Charan Singh, Sh. Nikhil & Ms. Priya		
10.	Year of construction: -	1995		
11.	Applicant's letter No: -	Online application No. 2025100313927 dated 12.02.2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement / Existing Fire Safety Arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	6.00 mtr.	6.00 mtr.	MR*
	• Gate width	5.00 mtr.	5.00 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	03 nos.	03 nos.	MR
	• Basements	02 nos.	02 nos.	MR
	b. Width of staircase			
	• Upper floors	1.25 mtr.	1.25 mtr. each	MR
	• Basements	1.25 mtr.	1.25 mtr. each	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01 no.	01 no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.00 mtr.	1.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Provided Mechanical	MR
	• Upper floors	Required	Provided Mechanical	MR
5.	Fire Extinguishers			
	• Total numbers	18 nos.	18 nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	02 nos.	02 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A

	• Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	MR
12.	Yard Hydrants			
	• Total number of hydrants	04 nos.	04 nos.	MR
	• Hose box	04 nos.	04 nos.	MR
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	2 X 900 LPM	2 X 900 LPM	MR
	• Head of pump	40 mtr.	40 mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	1,00,000 Ltrs	1,00,000 Ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Fireman's switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A

N/29


20.	Special Fire Protection System for Protection of special Risk, if any: ABC, CO ₂	MR
-----	---	----


*PNF - Provided but Non-Functional, *MR - Meeting Requirement, *NMR - Not Meeting Requirement

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Rules, if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/NDZ/2023/127 dated 02.03.2023, under Rule 35(6) of the Delhi Fire Service Rules 2010.

Accordingly, DFA is prepared and put up for kind perusal and signature please.


Manish Kumar
DO (CD)


Bhupender Prakash
ADO (CC)

Dy. CFO (AD2)


05/03/26

Principal Director

Dy. CFO to Issue.


06/03/26

Dy. CFO (AD2)


07/03/26

ADP (CC)

As approved R.T. letter is put up for signature pls.


10/03/2026

Dy. CFO (AD2)


11/03/26

MS

Upladeel