

d/pb

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/NDZ/2025/ 147

Dated: 11/03/2025

To

The Principal,  
Children Happy Public School, 520/30-A,  
Krishna Gali No. 14, Adarash Mohalla, Moujpur, Delhi-110053.

**Sub: Regarding Fire Safety Certificate in r/o Children Happy Public School, 520/30-A, Krishna Gali No. 14, Adarash Mohalla, Moujpur, Delhi-110053.**

Sir,

This has reference to your letter No. A-1/1 dated 19/02/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 25/02/2025 in the presence of Mrs. Kamlesh Sharma to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of **Ground Floor, 1<sup>st</sup> Floor, 2<sup>nd</sup> Floor & 3<sup>rd</sup> Floor**. However previous Fire Safety Certificate was issued to this premises vide letter No. F6/ MS/ DFS/2006/2628 dated 18/09/2006 for **Ground, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor only**. Following shortcomings were observed during the inspection:-

1. One staircase of width of 0.85mtr against requirement of two staircase of width of 1.50mtr each.
2. Hose reel hose not provided.
3. Fire Pump of capacity 450LPM not provided.
4. Overhead tank capacity of 10,000 ltr not provided.
5. Exit signage found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under :  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/Fire/Home /Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/Fire/Home /Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/Fire/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/Fire/Home/Forms)

Yours faithfully

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.