



234



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2026/SZ/09

Dated: 09/01/2026

FIRE SAFETY CERTIFICATE

Certified that the **CM Shri School** (Earlier Sarvodaya Kanya Vidyalaya) located at District Centre, Janakpuri, New Delhi-110018 (School ID: 1514017), having six blocks; Primary & Middle Block- Ground floor, New SPS Blk- Ground + 1 upper floor, Vocational Blocks- Ground floor only, Main Building- Ground + 02 upper floors and MP Hall- Ground floor only, owned/occupied by Directorate of Education, Govt. of NCT of Delhi, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/607 dated 01/06/2022. The premise was re-inspected by the officer concerned of this department on 30/12/2025 in the presence of Dr. Rajeev Ranjan (Principal) and found to have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 & Rule 33 of the Delhi Fire Service Rules, 2010 and that the school premise/building is fit for occupancy class "**Educational Group B**" with effect from 09/01/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/01/2026 at New Delhi by


7/1/26
(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Principal, CM Shri School (Earlier Sarvodaya Kanya Vidyalaya) located at District Centre, Janakpuri, New Delhi-110018

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

U-16

INSPECTION REPORT				
1.	Name & address of the building	CM Shri School (Earlier Sarvodaya Kanya Vidyalaya), District Centre, Vikas Puri, New Delhi-110018 (School ID: 1514017)		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	The school complex has six blocks; Main Bldg.- G+2, SPS Blk- G+1, Voc. Blk- G+1 (2nos), MP Hall/Audi= GF only, Pry & Middle Blk= GF only		
4.	Type of Case	Renewal		
5.	Details of previous FSC No.	F.6/DFS/MS/School/2022/SZ/607 Dt. 01/06/2022		
6.	Fire safety directives letter No.	DOE Circular dt. 01.03.2011 & NBC Part-IV		
7.	Date of Inspection	30/12/2025		
8.	Name of the Inspecting Officer	ADO (JKP)		
9.	Name and designation of Officer from the building side	Dr. Rajeev Ranjan (Principal)		
10.	Year of Construction	Before 2010 (Pry. Blk & Vocational Blks) 2019 (Main Bldg., MP Hall/Audi & N.SPS Blk)		
11.	Applicant's letter No.	Received through e-mail dated 16/12/2025 from mail id. skvdcvp@gmail.com		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 mtr	Provided	MR
	• Gate width	4.5 mtr	6.0 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2nos in M Bldg., 3nos in New SPS Blk & 01 No. in each Voc. Blk	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5m & 0.75m	1.50m each in M. Bldg. 1.5m each in N.SPS Blk, 1.50m in each Voc. Blk	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width of Corridor	1.50 mtr	2.95m in M Bldg., 1.5m in N SPS Blk & 1.5m in each Voc. Block	MR
	f. Door Size	1.0m in each Voc, Pry & Middle, 1.2m in M Bldg., N SPS Block & 2.0m in MP Hall/Audi (6 No's)	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	30 No's	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers in MB, MP Hall	One / Floor	Provided & functional	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05mm	05mm	MR

SP

N-17

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Wooden Stage in MP Hall	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM each in MB/ MP Hall	450 LPM each in MB & MP Hall	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr in M Bldg. 5,000 lts in MP Hall	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N-12

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were checked, tested at random and **found functional at the time of inspection**. The shortcomings earlier issued vide letter No. F.6/DFS/MS/School/2025/SZ/859 dated 03/12/2025 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate earlier issued vide letter no. F.6/DFS/MS/School/2022/SZ/607 dated 01/06/2022, **renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, **DFA is put up for approval & signature please.**

Santosh Kumar
01.01.26

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (JKP)

DO (SW)

[Signature]

RAJINDER ATWAL

Dy. CFO (S)

[Signature]
11/1/26
A.K. MALIK

Principal Officer

Dy. CFO to Secy.

[Signature]
02/01/26

[Signature]
Dy. CFO (S)

[Signature]
3/1/26
A.K. MALIK

DO (SW)

[Signature]

ADO - JKP

[Signature]

P.T.O