



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



44 8

No. F6/DFS/MS/WZ/2025/CNG/ 44

Dated:- 20/03/2026

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Station Located at CNG Station at Khasra No. 30/19, 10, 11, 12/1, 12/2, 12/3, 18, 19 & 20, 31, 15/1 & 15/2, Ghogha Dairy, Bawana Narela Road, Sannoht, Narela, New Delhi-110040, comprised of Ground Floor only owned/occupied by Indraprastha Gas Limited have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 05/03/2026 in the presence of Sh. Mohit (FM) and that the building/Premises is fit for occupancy "Hazardous Building" Group - J with effect from 20/03/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 20/03/2026 at New Delhi by.

*S.K. Dua*  
20/03/26

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service

*Re. OIC*  
19/04/26

Copy to: -

1. Sh. Ajay Khatri, GM (Fire & Safety), IGL Bhawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

412

## INSPECTION REPORT

1	Name & Address of the Building	CNG Station at Khasra No. 30/19, 10, 11, 12/1, 12/2, 12/3, 18, 19 & 20, 31, 15/1 & 15/2, Ghogha Dairy, Bawana Narela Road, Sannoath, Narela, New Delhi-110040		
2	Type of Occupancy	Hazardous "Group- J"		
3	Type of Case	New case (Ground Floor Only)		
4	Details of Previous NOC	Nil		
5	Fire Safety Directives Letter No	F6/DFS/MS/BP/CNG/2024/293 dated 12/09/2024		
6	Date of Inspection	05/03/2026		
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (BW/RN)		
8	Name & Designation of Officers from the building side	Sh.Mohit (FM)		
9	Year of construction	2024-25		
10	Applicant letter No.	IGL/F&S/2025/15/160/1 dated 10/11/2025		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC-IV/OISD Requirements/as per Directive letter issued dated 12/09/2024	Provided at Site	Remarks NR/NMR
1	<b>Access to Building.</b>			
	• Road width	60 m	Provided	MR
	• Gate width	-N/A-	-N/A-	-N/A-
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	-N/A-	-N/A-	-N/A-
	➤ Basement floor.	-N/A-	-N/A-	-N/A-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	<b>d) No. of continuous staircase to terrace</b>	-N/A-	-N/A-	-N/A-
	<b>e) Width of corridor</b>	-N/A-	-N/A-	-N/A-
	<b>f) Door size</b>	01 m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4	<b>Smoke Management system.</b>			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
5	<b>Fire Extinguishers.</b>			
	• Total numbers	75 kg-5 09 kg-15 4.5 kg-4	24	MR
	• Types	DCP 09 kg & CO <sub>2</sub> 75 kg	Provided	MR
	• ISI Marking	ISI marked	Provided	MR

N/3

<b>6. First Aid Hose Reels.</b>				
	• Total numbers on each floor	-N/A-	-N/A-	-N/A-
	• Length of hose-reel hose.	-N/A-	-N/A-	-N/A-
	• Nozzle Diameter	-N/A-	-N/A-	-N/A-
<b>7 Automatic fire detection &amp; alarming system.</b>				
	• Type of detectors	Gas & Flame	Provided in compressor	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	-N/A-	-N/A-	-N/A-
<b>10. CO<sub>2</sub> flooding system</b>				
	• Ground Floor	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11. Internal Hydrants.</b>				
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
<b>12. Yard Hydrants.</b>				
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
<b>13. Pumping arrangements.</b>				
	• <b>Ground Level</b>			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
<b>14. Captive water storage for firefighting.</b>				
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	-N/A-	-N/A-	-N/A-
<b>15.</b>	<b>Exit Signage</b>	Required	Provided	MR

R X

N/A

<b>16. Provision of Lifts.</b>				
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
<b>17</b>	<b>Standby Power Supply</b>	-N/A-	-N/A-	-N/A-
<b>18. Refuge Area</b>				
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
<b>19. Fire Control Room.</b>				
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	N/A-	N/A-	N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Generator operated water cum foam mist. trolley & 02 nos. Handy Detector HX2D	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - CNG Station is running with 01 no. Cascade, 01 no. Compressor on terrace floor & 06 nos. CNG Dispenser.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety requirements under the rules, grant of Fire Safety Certificate is **recommended** under rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is put up for approval and signature please.

*Aman Kumar Lathar*  
10/03/26  
Aman Kumar Lathar  
ADO (BW/RN)

*AO (G/2)*  
*ADP*  
10/03/2026

*Sy. C/S (G/2)*  
*R.V.P.*  
10/03/26

*Pr. Director*

*My. C/S to Genm.*

*My. C/S (G/2)*  
*F.T. Pl.*  
11/03/26

*ADO (BW)*  
*R.V.P.*  
20/03/26  
*F.F. letter is put-up for your signature, 10/03/26*  
*11/03/26*