



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

C/36

No. F6/DFS/MS/WZ/2025/CNG/ 559

Dated:- 11/10/2025

FIRE SAFETY CERTIFICATE

Certified that the CNG Station Located at Peera Garhi, North of DTC depot, Delhi-110041 owned/occupied by Indraprastha Gas Limited was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/2022/CNG/430 Dated 28/09/2022. The said premise was re-inspected by the officer concerned of this department on 24/09/2025 in the presence of Sh. Chitvan Vyas, Dy. Manager (F&S, IGL) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Hazardous Building" Group - J with effect from 11/10/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 11/10/2025 at New Delhi by..

M.K. Chattopadhyay
Dy. Chief Fire Officer

Copy to: -

1. Sh. Ajay Khatri, GM (Fire & Safety), IGL Bhawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	CNG Station, Peera Garhi, North of DTC depot, Delhi-110041		
2	Type of Occupancy	Hazardous "Group- J"		
3	Type of Case	Renewal		
4	Details of Previous NOC	F6/DFS/MS/WZ/2022/CNG/430 Dated 28/09/2022		
5	Fire Safety Directives Letter No	OISD 179		
6	Date of Inspection	24/09/2025		
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JWP)		
8	Name & Designation of Officers from the building side	Sh. Chitvan Vyas, Dy. Manager (F&S)		
9	Year of construction	2000		
10	Applicant letter No.	IGL/F&S/2025/15/45/1 dated 07/08/2025		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC-IV/OISD Requirements/ as per earlier FSC issued dated 28/09/2022	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 m	30 m	MR
	• Gate width	Required	Abut on Road	MR
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-N/A-	-N/A-	-N/A-
	➤ Basement floor.	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	01 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
5.	Fire Extinguishers.			
	• Total numbers	14 nos.	25 nos.	MR
	• Types	DCP & CO ₂	DCP 75 kg wheel mounted – 05 Nos. DCP 9 kg – 17 Nos. CO ₂ 4.5 kg – 03 Nos.	MR
	• ISI Marking	ISI Marked	Provided	MR

6.	First Aid Hose Reels.	-N/A-	-N/A-	-N/A-
	• Total numbers on each floor	-N/A-	-N/A-	-N/A-
	• Length of hose-reel hose.	-N/A-	-N/A-	-N/A-
	• Nozzle Diameter	-N/A-	-N/A-	-N/A-
7	Automatic fire detection & alarming system.			
	• Type of detectors	Gas & Flame Detector	Provided in Compressor	MR
		-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	Required	Provided	MR
8.	MOEFA	-N/A-	-N/A-	-N/A-
9.	Public Address System			
10.	CO₂ flooding system			
	• Ground Floor.	Required in compressor area	Provided	MR
		-N/A-	-N/A-	-N/A-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling			
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	-N/A-	-N/A-	-N/A-
15.	Exit Signage	Required	Provided	MR

Re.

16.	Provision of Lifts.			-N/A-
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided	
18.	Refuge Area			-N/A-
	<ul style="list-style-type: none"> Total area Location 	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			-N/A-
	<ul style="list-style-type: none"> Detector System Panel. Flow Switch Panel. PA system Panel. Battery backup Building floor plan 	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	DCP Flooding in cascade, CO ₂ Flooding in Compressor & in addition 01 Generator operated water cum foam mist trolley	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- CNG Station running with 02 nos. cascade, 02 nos. compressor & 06 nos. dispenser.

In View of the deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, **renewal of FSC** issued vide letter no. F6/DFS/MS/WZ/2022/CNG/430 Dated 28/09/2022 **is recommended** under the rule 37 of the Delhi Fire Service rule, 2010 under the DFS Act 2009.

Accordingly DFA is put up for approval and signature please.

Aman Kumar Lathar
29/09/22
Aman Kumar Lathar
ADO (JWP)

DCFO (wr)
DCFO
principal Director
29/9

By. Cfo to *DCFO*
DCFO (wr)
29/10/22

ADO (JWP)

DCFO/...
Dated... 29/09/2022