



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No.F.6/DFS/MS/C-Hall/2025/NDZ/ 627

Dated: 17/12/2025

To,

The Executive Engineer (E),
Delhi Development Authority
Office of the Executive Engineer Electrical Division No-01
Sed Bed Park, School Block, Shakarpur,
New Delhi-110092.

Sub:- Regarding renewal of Fire Safety Certificate in r/o Multipurpose Community Hall with Sport Facility, Geeta Colony, Delhi-110031.

Sir,

This has reference to your letter no. nil dated 30/10/2025 received through outdoor diary No. 7666 dated 30/10/2025, on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 06/12/2025 in presence of Sh. Sandeep Kumar (A.E.). The premises is comprised of ground plus three upper floors. The following shortcomings were observed during the time of inspection.

1. First-Aid Hose reels provided but not functional.
2. Automatic Fire Detection and Alarming System found nonfunctional.
3. MOEFA provided but not functional.
4. Hooter provided but not functional.
5. Automatic sprinkler system provided but not functional.
6. Down-comer provided but not functional.
7. Pumping Arrangements are found non-functional.

In view of above shortcomings, the **application for renewal Fire Safety Certificate is rejected**. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


17/12/25

(Dr. S. K. TOMAR)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

o/c e.