



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/2025/SZ/06

Dated: 06 / 01 / 2026

To

The Executive Engineer (E),
 E-mail: eeeld10@dda.org.in
 Delhi Development Authority,
 Electrical Division-10, B2B,
 Janakpuri, New Delhi-110058.

Sub: Regarding renewal of Fire Safety Certificate in r/o "Community Hall" located at Pkt 20-B, Near Sitapuri, Dwarka, New Delhi for DDA


Sir,

This has reference to e-mail dated 10/12/2025 received from mail Id. eeeld10@dda.org.in along with attachment. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 24/12/2025 in presence of Sh. Kuldeep Singh (Supervisor) to verify the availability and operability of fire protection measures. During course of inspection, the shortcomings observed are as below.

1. Fire check doors provided for the protection of exits/lift lobby found damaged/faulty.
2. smoke exhaust system found provided but not integrated with MCPs.
3. Manually operated electrical fire alarm system found non-functional.
4. Public address system provided but non-functional.
5. Exit signage's found removed at some locations.
6. Lift grounding switch found non-functional and lift signage removed.

In view of the above, application for renewal of fire safety certificate cannot be considered & rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier/management.

Yours faithfully,


 21/1/26
 (A.K. Malik)
 Dy. Chief Fire Officer (SZ)
 Delhi Fire Service

Copy to: -

1. The Joint Director (C&I), DDA, Building Section, Vikas Sadan, INA, New Delhi-110023

