



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

282
75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/154

Dated: -20/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Coral Plaza, 2039/7, Gali No.-7, Chuna Mandi, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026013001072 dated 30/01/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 07/02/2026 in the presence of Sh. Arun Chopra, Owner and following shortcomings were observed: -

1. Width of corridor was 1.17 mtr. against required width of 1.50 mtr.
2. Automatic operation of Fire pump found removed.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


19/2/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

o/c BP

Copy to: -

1. The Manager, M/s Coral Plaza, 2039/7, Gali No.-7, Chuna Mandi, Paharganj, New Delhi - 110055.