

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No. F.6/DFS/MS/School/2026/SZ/ 40

Dated: 16/03/2026

**FIRE SAFETY CERTIFICATE**

Certified that the Building Centre for Cultural Resources and Training (**Except Auditorium**) located at Plot 15/A, Sector – 7, Dwarka, New Delhi – 110075, comprised of small basement, Ground + 2 Upper Floor was issued FSC vide letter No. F.6/DFS/MS/SZ/2022/27 dated 19.01.2022. The premises was re- inspected by the officer concerned of this department on dated 23.02.2026 in the presence of Sh. Sandeep (Typist), Sh. Ramboo (Plumber), and found that the building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class “Educational Building” (**Except Auditorium**) w.e.f. 16/03/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 16/03/2026 at New Delhi by.



(A.K. Malik)  
Dy. Chief Fire Officer  
South Zone

Copy to: -

1. The Dy. Director, Centre for Cultural Resources and Training located at Plot 15/A, Sector- 7, Dwarka, New Delhi – 110075.
2. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

**: - for information regarding use of basement.**

**Conditions for the validity of fire safety certificate: -**

1. The Auditorium shall not be occupied/ used for any purpose without getting FSC from this department.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. Basement shall be used as per BBL/UBBL.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form ‘J’ [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/30  
**INSPECTION REPORT**

1. Name & address of the building: Centre for Cultural Resources and Training  
Located at Plot 15/A, Sector 7, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (**Small Basement + Ground+ 2 Upper Floors**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2022/SZ/27 Dated 19/01/2022
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/96/487 Dated-10/04/1996.
6. Date of inspection : 23/02/2026
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Sandeep (Typist) Sh. Ramboo (Plumber)
9. Year of Construction : 2003
10. Applicant's letter No. CCRT/11013/11/2018/1151 Dated-27/01/2026

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/19,N,20,N21	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	05 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	4 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 m	4 Nos Provided Old Case	MR (old case)
	• Basements	1.5 m	2 Nos Provided Old Case	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	03 Nos.	03 Nos	MR
	e. Width Of Corridor	Required	1.70 mtr	MR Old Case
	f. Door Size	01 mtr	01 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust fan provided	MR
	• Upper floors	12 are charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	26 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	CO <sub>2</sub> , ABC, DCP	MR
	• IS marking	ISI marked	ISI marked	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	03 Nos. each floor	Provided	MR
		30 m	30 m	MR
	• Length of hose reel hose	05 mm	05 mm	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Ground floor near staircase	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Battery Backup	Provided	MR
	• Hooters' Location	Corridor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	03 Nos. each floor	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	02	02	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	1620 lpm	1620 lpm	MR
	➤ Head of main pump	56 mtr	56 mtr	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey pump out put	180 lpm	180 lpm	MR
	➤ Jockey pump head	56 mtr	56 mtr	MR
	➤ Standby Pump out put	1620 lpm	1620 lpm	MR
	➤ Standby Pump Head	56 mtr	56 mtr	MR
	➤ Auto starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the pump	40 mtr	30 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	1,00000 ltr	Provided	MR Old Case
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA

17	Standby power supply	Required	DG Set	MR
18	Refuge Area	NA	NA	NA
	➤ Total area	NA	NA	NA
	➤ Location			
19	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2. Fire extinguisher provided near electric panel	MR

**Note:- Auditorium block is found under maintenance. If agreed the FSC may be issued to rest of the CCRT building except Auditorium block.**

The fire protection systems provided in the building were test checked and found functional at the time of inspection.  
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the ~~MOU~~ issued vide letter F-6/DF/S/MS/2022/S/27 Date 19/01/2022 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*R.K. Yadav*  
 Signature of the Inspecting Officer  
 Name R.K. Yadav  
 Designation ADO/DWK

*DO(SW)*  
*[Signature]*  
 RAJINDER KIWAL

*DO(SW)*

*[Signature]*  
 26/2/26  
 A.K. MALIK

Principal Director

Why application?

By. CFO to Secy  
 Member & put up. [Signature]

By. CFO (Secy) 27/02/26

*[Signature]*  
 2/3/26  
 A.K. MALIK

DO/SW

The application for renewal of FSC was received in hard copy alongwith Form J under sub-rule (1) of Rule 37 of DPB Rules 2010

N/32.

Ref: Prepage N/32

Accordingly, the application was considered in hard copy and processed further. The case may be considered. Also directions may kindly be issued in such cases for future action, submitted, please.

~~Defo (SZ)~~

  
3/3/26


RAJINDER ATWAL

- ① I agree with DO (SW) remark at N/32 as statutory provisions cannot be denied to a citizen. However applicants without form 'I' has already been replied to apply through online portal.
- ② 'B' above may be considered.

  
3/3/26  
A.K. MALIK

~~Principal Officer~~

We have already instructed <sup>our officers</sup> to inform them to apply through online. Yes, Statutory provisions

can't be denied, but nothing prevents them to ask them to use online system. The use of digital  platform? They what?

My. CFO (SZ)

03/03/26

Siz

N/24

I fully agree with your remarks on N/33, in this context - may please see Point 2 of order dated 16/1/26, format for the same of Rule-37. Accordingly, DPA may be approved of RSC placed on file.

~~Principal Director~~

~~Akmalik~~  
7/3/26

A.K. MALIK

This note requires further discussion.

~~Signature~~  
09/02/26

~~Dy. C.S. (S2)~~

Spastees. The clear instruction has to be given to all nominated authorities to encourage the applicants to apply through online.

This is approved by C.S. to ~~Spastees~~.

~~Signature~~  
10/02/26

~~Dy. C.S. (S2)~~

~~Akmalik~~  
10/4/26

A.K. MALIK

~~D.C. (S2)~~

~~Signature~~  
11/3