

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2025/SZ/ 17

Dated. 09/01/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the Name & Style of **M/s DASAPRAKASH** (A Unit of Das Kitchen) located at H-36, **Ground & Mezzanine floor**, Outer Circle Connaught Place, New Delhi 110001 in the building Comprised of Ground, Mezzanine plus Two upper floors, but restaurant running at Ground & Mezzanine floor only owned/occupied by (A Unit of Das Kitchen) was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH//2021/253 dated 27/09/2021. The restaurant premise was re-inspected by the officer concerned of this department on 02/01/2025 in the presence of Mr. Ajay Kumar (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant at Ground & Mezzanine floor only)** and **validity upto 31/03/2028** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/01/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DEHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police, Lic/Branch 1<sup>st</sup> Floor PS Defence Colony, New Delhi 110049 (Ref. MCD Portal ID 2024121317999 dated 13/12/2024)
2. The Medical Officer of Health, Health Department, Palika Kendra, New Delhi.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

p/17

## INSPECTION REPORT

1	Name & Address of the Building	M/s DASAPRAKASH (A Unit of Das Kitchen) at H-36, Outer Circle Connaught Place, New Delhi		
2	Type of Occupancy	Group-D Assembly Building. (Eating House)		
3	Building Comprised of	Ground, Mezz. + Two upper Floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH//2021/253 dated 27/09/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	02/01/2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Ajay (Manager)		
10	Year of construction	1994	Restt. Running at Ground & Mezz. Floor	
11	Applicant letter No.	MCD Portal ID 2024121317999 dated 13/12/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	06 mtr	09 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 No's	03 No	MR
	➤ Basement floor.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.25 m each	1.50 mtr, 1.20 mtr & 1.0 mtr	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	2 mtr	2 mtr	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	• Basement	12 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	10 Nos	10 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC-06 & CO <sub>2</sub> -04	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR

07/18

17

	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>	5mm	Provided	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Ground/ upper floors.</li> </ul>	N/A	Provided	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	100mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	01 No	Provided	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	01 No	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450 LPM	2 x 450 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	20,000 Ltrs	20,000 ltrs	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	N/A	N/A	N/A

02/19

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 456 dated 16/10/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2021/253 dated 27/09/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO (BCP)

6/11/25

DO (CD)

6/11/25

~~Dy. C.F.O. (2022)~~

~~21/10/25~~

~~C.F.O.~~

~~8/11/25~~

~~Director~~

~~8/11/25~~

~~8/11/25~~

As approved, F.T. letter in partip for your signature A

9/11/25

~~Director~~  
9/11/25

Uploaded  
09/11/25