



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आफ़ादीन
अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/ 193

Dated 03/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s **Dasaprakash** (A Unit of Das Kitchens) located at Unit No. 105, first floor, LSC Cum Office Complex, Aurobindo Place, Hauz Khas, New Delhi – 110016

Sir,

This has a reference to MHA application No. 2026012901035 dated 30/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 23/02/2026 in the presence of Mr. Anurag Yadav (Manager) and observed that building comprised of Ground plus three upper floors but restaurant running on first floor only, following shortcomings were observed during time of inspection:

1. Smoke Management system provided but not functional.
2. First-Aid-Hose Reel provided but not functional.
3. MOEFA found removed.
4. Internal Hydrants provided but not functional.
5. Terrace fire pump provided but not functional.
6. Overhead water storage tank of capacity 15,000 liters provided against requirement 20,000 liters.
7. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
o/c @