

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F6/DFS/MS/EH/2025/WZ/152

Dated: 26/04/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the Name & Style of **M/s DAWAT E MEHFIL** located at GA 7 & 8, Metro Walk Mall, Sectro-10, Rohini, Delhi 110085 in the building comprised of Ground and First floor owned/ occupied by A Unit of Waliaz Hospitality was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2022/Restaurant/WZ/97 dated 21.04.2022. The premises was re-inspected by the officer concerned of this department on 22.04.2025 in the presence of Mr. Pradeep Shah and found the premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for **Class -D(Assembly Building)** occupancy and **validity upto 31/03/2028** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....26/04/2025 at New Delhi by

  
**(ATUL GARG)**  
**DIRECTOR**  
**DELHI FIRE SERVICE**

Copy to:-

1. The Addl. Commissioner of Police, Lic/Branch, 1<sup>st</sup> Floor Defence Colony, New Delhi 110049. (Ref. MCD Portal ID 2025030803088 dated 29.03.2025)

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : M/ s Dawat-E-Mehfil (A Unit of Waliaz Hospitality ), Metro Walk Mall, GA-7 & 8Sector.-10, Rohini, Delhi-85.  
: Assembly (Restaurant) Ground floor
2. Type of Occupancy : Renewal
3. Type of Case : F6/DFS/MS/2022/Restaurant/WZ/97 dated 21.04.2022
4. Details of previous NOC : F6/DFS/MS/2023/WZ/503 dated 30/10/2023 Metro Walk
5. Fire Safety directives letter No : 22/04/2025
6. Date of inspection : 22/04/2025
7. Name of the Inspecting Officers : ADG/ (SOP) AL
8. Name and designation of officers from the building side : Mr. Pradeep Shah
9. Year of Construction : 2006 -07
10. Applicant's letter No. : MCD Portal ID 2025030803088 dated 29.03.2025

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09m	10m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Restaurant running at ground floor only		
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.50 mtr	1.2m & 1.0 m	old case
3	<b>Compartmentation. For the restaurant</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers For the restaurant</b>			
	• Total numbers	05nos	06nos	MR

N/33



	<ul style="list-style-type: none"> <li>Types</li> <li>ISI marking</li> </ul>	ABC/Co2	ABC-05 /Co2-01	MR
		Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	Total numbers on each floor	01	01	MR
	Length of hose reel hose	30 m	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	Basement	NA	NA	NA
	Upper Floor	Required	Provided	MR
	Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants for the Mall</b>			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	<b>Yard Hydrants. For the Mall</b>			
	Total number of hydrants	Required	Provided	MR
	Hose Box	Required	Provided	MR
13	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> </ul>	Provided & Maintained by Metro Walk Mall		
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180 lpm	180 lpm	MR
		40m	40m	MR
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
		<ul style="list-style-type: none"> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	450 lpm	450 lpm
	40m		40m	MR
	Required		Provided	MR
	Required		Provided	MR
14	<b>Captive Water Storage for fire fighting</b>			
	Underground tank capacity	NA	NA	NA

	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>● Overhead Tank capacity</li> </ul>	NA	NA	NA	
		Required	Provided	MR	
		NA	NA	NA	
		Required	Provided	MR	
15	Exit Signage.	Required	Provided	MR	
16	Provision of Lifts.				
		● Pressurization of Lift Shaft	NA	NA	NA
		● Pressurization of Lift lobby	NA	NA	NA
		● Communication In lift Car	NA	NA	NA
		● Fireman's Grounding Switch	NA	NA	NA
		● Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR	
18	Refuge Area.				
		➤ Total Area	N/A	N/A	N/A
		➤ Location	N/A	N/A	N/A
19	Fire Control Room				
		● Detector System Panel	NA	NA	NA
		● Flow Switch Panel	N/A	N/A	N/A
		● PA System Panel	N/A	N/A	N/A
		● Batter backup	N/A	N/A	N/A
		● Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA	

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/2022/Restaurant/WZ/97 dated 21.04.2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

*[Handwritten Signature]*  
23/4/2025

Signature of the Inspecting Officer  
Name: - Rajesh Kumar  
Designation:- ADO/BCP

DO (NW)  
DCFO/628-1114  
dated 25/4/25

*[Handwritten Signature]*  
25/04/2025  
By CFO (WZ)

*[Handwritten Signature]*  
25/4/2025  
Director

*[Handwritten Signature]*  
25/4/25