

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/EH/NDZ/2026/ 50

Dated: 02/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s DDCA Restaurant Lounge, located at Arun Jaitley Stadium, Ferozshah Kotla Ground, New Delhi - 110002 comprised of Ground + 04 Floors but Restaurant running at 4th Floor only. The premises was inspected by the officers concerned of this department on 10/03/2026 in the presence of Sh. Deepak, Manager and found that the said restaurant premises has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class - **Assembly (Group D) for Restaurant at 4th Floor only** with effect from 02/04/2026 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 02/04/2026 at New Delhi by.


24/1/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi.: Online ID – 2026030502395 dated 05/03/2026.
2. The Manager, M/s DDCA Restaurant Lounge, Arun Jaitley Stadium, Ferozshah Kotla Ground, New Delhi - 110002.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for Restaurant at 4th Floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction, electric installation, set bac area etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building	M/s DDCA Restaurant Lounge, Arun Jaitely Stadium, Ferozshah Kotla Ground, New Delhi - 110002.		
2.	Type of occupancy	Assembly Occupancy - Eating House (Restaurant)		
3.	Building is Comprised of	Ground + 04 Floor only		
4.	Type of case	But Restaurant running at 4 th Floor only		
5.	Details of previous NOC/FSC	Fresh		
6.	Fire safety directives No.-	F.6/MS/DFS/Stadium/2009/2526 dated 13/08/2009		
7.	Date of inspection: -	F.6/DFS/MS/BP/2005/486 dated 04/03/2005		
8.	Name of the inspecting officer: -	10/03/2026		
9.	Name & designation of officer From the building side: -	Sh. Manish Kumar, DO (CD) Sh. Bhupender Prakash, ADO (CC)		
10.	Year of construction: -	Sh. Deepak, Manager		
11.	Applicant's letter No: -	2010		
		MCD Online ID 2026030502395 dated 05/03/2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R	Requirement/ Existing fire safety arrangements as per directives dated 04/03/2005	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	6.0 mtr.	6.0 mtr.	MR
	• Gate width	6.0 mtr.	6.0 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	1.50 mtr.	2.00 mtr. each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02 nos.	02 nos.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2.00 mtr.	2.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electric ^l shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided Natural	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	12 nos.	MR
	• Types	ABC/CO ₂	ABC/CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	02 nos.	02 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Required	Provided	MR

8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			N/A
	• Basement	N/A	N/A	MR
	• Upper Floors	Required	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	
11.	Internal Hydrants			MR
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose box per floor	02 nos.	02 nos.	
12.	Yard Hydrants			MR
	• Total number of hydrants	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	
13.	Pumping Arrangement (Common Fire Pump Room is maintained for entire stadium complex)			
	Ground level			
	• Discharge of main pump	2850 LPM	2850 LPM	MR
	• Head of main pump	40 mtr.	40 mtr.	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump output	180 LPM	180 LPM	MR
	• Jockey pump head	40 mtr.	40 mtr.	MR
	• Stand by pump output	2850 LPM	2850 LPM	N/A
	• Stand by pump head	40 mtr.	40 mtr.	MR
	• Auto starting/Manual stopping	Required	Provided	MR
	Terrace level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting (Common Underground Fire Water Tank is maintained for entire stadium complex)			
	• Underground tank capacity	1,00,000 Ltrs	2,00,000 Ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	Required	provided	MR
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, if approved, we may issue the FSC to the Restaurant required under the Rule 33 of Delhi Fire Service Rules 2010. The last date for deemed approval is 03/04/2026.

Accordingly, DFA is prepared and put up for perusal and signature please.

[Signature]
25/03/26
Manish Kumar
DO (CD)

[Signature]
25/3/2026
Bhupender Prakash
ADO (CC)

Dy. CFO (NDZ)

[Signature]
27/3/26

Principal Director

- 1) Noting ^{side} file page should be operational
- 2. Approved.
- 3. Dy. CFO to Issue.
- 4. Resubmit for Pt. No 1. above

[Signature]
20/03/26

Dy. CFO (NDZ)

[Signature]
11/4/26

ADOC (B.P)
L.S. No. 2 Complied, F.T. is put up for signature pls Resubmitted please.

Dy. CFO (NDZ)

[Signature]
01/4/2026

As directed, Resubmitted please

Principal Director

[Signature]
11/4/26

[Signature]
02/04/26

[Signature]
21/4/26