



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-36
75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/ 771

Dated: - 11/08/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Delhi Fab, 1657/1, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026071409802 dated 14/07/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 01/08/2026 in the presence of **Sh. Mayank, Manager** and following shortcomings were observed: -

1. Alternate staircase of width 1.50 mtr. is not provided in basement.
2. Width of corridor provided 1.50 mtr. against the required width of 1.80 mtr.
3. Smoke management system was not provided in basement.
4. Further, information provided in building plans submitted with online application is mismatched with the site.

Keeping in view of the above **shortcomings**, the application for issuance of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


11/8/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

01C BR

Copy to: -

1. The Manager, M/s Delhi Fab, 1657/1, Paharganj, New Delhi - 110055.