

C-220

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2025/BP/134

Dated: 28/03/2025

To,

The Chief Architect
New Delhi Municipal Council
Palika Kendra
New Delhi 110001

Subject: Regarding clearance of building plans from fire safety point of view in r/o construction of assembly building at driving range for Delhi Golf Club, Dr. Zakir Hussain Marg, New Delhi.

Sir,

Please refer your online ID No. 3317C-124 dated 17.03.2025 on the above cited subject. In this connection, this is to inform you that the matter is examined and following shortcomings are observed:

1. Travel distance is not meeting the requirement as per clause 7.8 of UBBL 2016.
2. Fire and life safety arrangements as per part 4 NBC 2016 are not proposed on the plans.

Accordingly the case is rejected.

Yours faithfully

(Atul Garg)
Director

011 23414000