



No. F6/DFS/MS/School/SZ/2025/1356

Dated: 27/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029, building comprised of Basement, ground plus three upper floors (one block) and Ground plus Two upper floors (one block) was issued FSC vide letter No. F6/DFS/MS/School/2021/SZ/697 dated 02/09/2021. The said premises was re-inspected by officer concerned of this department on 18/11/2025 in presence of Mrs. Ruby Malhotra (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational Building" (Group - B) with effect from 27/11/2025 for a period of Three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010 & also conditions printed bellow.

Issued on 27/11/2025 at New Delhi by.


(A.K. Malik)

Dy. Chief Fire Officer

Delhi Fire Service
etc @

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, old Secretariat, New Delhi-110054.
2. The Principal, Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029.		
02.	Building is comprised of	B+G+3 (One Block) & G+2 (One Block)		
03.	Type of occupancy	Educational Building		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2021/SZ/697 dated 02/09/2021		
06.	Fire safety directives letter no.	Nil		
07.	Date of inspection	18/11/2025.		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (BCP)		
09.	Name of the designation of officer from the building side	Mrs. Ruby Malhotra (Principal)		
10.	Year of construction	1998		
11.	Applicant's letter no.	Outdoor dairy no. 6505 dated 26/09/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	Required	12 mtr.	MR
	B Gate width	Required	05 mtr.	MR
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos. each block	A Block-02 B Block-05	MR
	C Basement	02 Nos	05	MR
	B Width of staircases			
	a Upper floor	1.50 mtr each	A block-1.80m each B block -1.80m,1.31m x2,1.08m x2, 2.3m,1.2m,2.8m,0.97 m&1.31m	MR
	C Basement	Required	Provided	MR
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	1.5 m	Provided	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	30 ACPH	Exhaust fan provided	MR
	B Upper floor	12 ACPH	Provided	MR
05.	Fire Extinguisher:			
	A Total numbers	Required	48 nos.	MR
	B Types	ABC	ABC Type	MR
	C ISI marking	ISI Mark	Provided	MR

06. First-Aid-Hose Reel:				
A	Total numbers of each floor	03 nos	Provided	MR
B	Length of hose reel hose	30 m	Provided	MR
C	Nozzle diameter	05 mm	Provided	MR
07. Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
08. MOEFA:				
		Required	Provided	MR
09. Public Address System:				
		N/A	N/A	N/A
10. Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants:				
A	Size of riser/down-comer	Required 100 mm	100 mm	MR
B	Number of hydrants per floor	Required 01 nos	01 No each block	MR
C	Hose box	Required 01	01 No each block	MR
12. Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13. Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	900 LPM	450+450 LPM	MR
B	Head of the pump	40 m	Provided	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR
14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 ltrs	10000+5000+5000 ltrs	MR

11/23

Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029

15.	Exit Signage:	Required	Provided	MR
16.	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17.	Standby Power Supply:		NA	N/A
18.	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19.	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:		NA	N/A

The Fire protection systems provided in the building were text checked at random and found functional at the time of inspection. The shortcoming issued by this department vide letter no. F6/DFS/MS/School/2024/SZ/674 dated 03/10/2024 has been complied.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/School/2021/SZ/697 dated 02/09/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended for approval.


19/11/2025

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO/BCP

DO/SD


20/11/25

Ravinder Singh

07/10/2024


20/11/25

A. K. MALIK

Principal Director

my. cfs to Issue.



20/11/25