



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

C-33

No. F.6/DFS/MS/Banquet/NDZ/2026/ 151

Dated: 19/02/2026

To,

Sh. Navin Kumar Gupta,  
M/s Diamond Crown Banquets (Aunit of Bobby Tikkiwala India Pvt. Ltd.)  
Unit No. G-1, 101-201 PD Area Karkardooma Metro Station,  
Delhi-110092.

**Subject:- Application for issuance of Fire Safety Certificate in r/o M/s Diamond Crown Banquets (Aunit of Bobby Tikkiwala India Pvt. Ltd.) located at Unit No. G-1, 101-201 PD Area Karkardooma Metro Station, Delhi-110092.**

Sir,

This has reference to MCD online application ID No. 2026011600591 dated 17/01/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 06/02/2026 in presence of Sh. Navin Kumar Gupta. The premises is comprised of basement, Ground plus two upper floors but banquet hall is running on ground to second floor of the building only. The following shortcomings were observed during the time of inspection.

1. Fire check door found removed from the 2.0 meter wide main staircase.
2. Smoke management system found removed in the banquet halls.
3. First-Aid hose reel found but not functional (damage).
4. Down-comer's hose boxes found empty.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S. K TOMAR)

DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

o/c r.

Copy to:-

The Commissioner, MCD, Civic Centre, New Delhi  
MCD ID No. 2026011600591