



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

C-62



No. F.6/DFS/MS/EH/WZ/2026/15

Dated: 05/01/2026

To,

Sh. Vijaypal Singh Bisht
M/s Dilli Darbar
Unit 114 to 121, 112, 113 & 124, 1st Floor,
Plot No. 15, N.N. Mall, Mangalam Place, Sec. 03,
Rohini, New Delhi-110085

Subject: - Application for renewal of Fire Safety Certificate in r/o M/s Dilli Darbar Located at Unit 114 to 121, 112, 113 & 124, 1st Floor, Plot No. 15, N.N. Mall, Mangalam Place, Sec. 03, Rohini, New Delhi-110085.

Sir,

This has reference to MCD application ID No. 2025120915537 dated 09/12/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 24/12/2025 in presence of Manager. The restaurant is running 1st floor of the building. The following shortcomings were observed during the time of inspection.

1. Second exit found closed. which goes through the kitchen.
2. Fire check door found removed in the kitchen.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

05/01/26
(S. K. DUA)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c p.

Copy to:-

The Commissioner, MCD, Civic Centre, New Delhi
MCD ID No. 2025120915537