



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



No F 6 / DFS / MS / 2025 / EH / SZ / 31

Dated: 16/01/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Dirty Good (A Unit of DG Bistro Pvt. Ltd.) located at Block-1 & Hut Building at Plot No. 7 A, Ground Floor, Netaji Nagar, Sudhir Tyagi Marg, Opposite Africa Avenue, Ring Road, New Delhi- 110023 in a building comprised of Ground Floor Only was issued FSC by this department vide letter No F6/DFS/MS/EH/2022/SZ/20 dated 18.01.2022. The premise was re-inspected by the officer concerned of this department on 09.01.2025 in the presence of Mr. Karan (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy "Assembly (Group D)" with effect from 16/01/2025 and valid up to 31/03/2028 in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/01/2025 at New Delhi, by

(Ajul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Additional Commissioner of Police (Lic.), First Floor, Police Station, Defence Colony, New Delhi.
2. MCD Portal, ID No. 2024122418331.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.delehlhlic.gov.in>) along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : M/s Dirty Good (A Unit of DG Bistro Pvt. Ltd.) located at Block-1 & Hut Building at Plot No. 7 A, Ground Floor, Netaji Nagar, Sudhir Tyagi Marg, Opposite Africa Avenue, Ring Road, New Delhi- 110023.
2. Type of Occupancy : Assembly (Restaurant).
3. Building Comprised of : Ground Floor only
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/EH/2022/SZ/20 Dated 18/01/2022
6. Fire Safety directives letter No : F6/DFS/MS/2014/170 Dated 16/06/2014
7. Date of inspection : 09/01/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers :  
From the building side : Mr. Karan (Manager)
10. Year of Construction : 2014 as per MHA Portal
11. Applicant's letter No. : MHA Application ID No. 2024122418331 dated 26/12/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per inspection report dated 10/01/2021	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	Road width	6 m	Provided	MR
	Gate width	5 m	Provided	MR
	Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	Upper Floors	NA	NA	NA
	Basements	NA	NA	NA
	b. Width of staircases			
	Upper Floor	NA	NA	NA
	Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2 x 1.5 m	Provided	MR
3.	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	Basements	NA	NA	NA
	Ground floor	Required	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	Total numbers	06 Nos.	10 Nos.	MR
	Types	ABC/Co2 Type	Provided	MR
	IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA

N-56

MR  
Special Fire Protection

		Required	Provided	
8.	<b>MOEFA</b>			NA
9.	<b>Public Address System</b>	NA	NA	
10.	<b>Automatic Sprinkler System</b>			NA
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	
11.	<b>Internal Hydrants</b>			MR
	Size of riser/down-comer	Required	Provided	MR
	Number of hydrants per floor	Required	Provided	MR
	Hose Box	Required	Provided	MR
12.	<b>Yard Hydrants</b>			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	Ground Level			
	Discharge of main Pump	NA	900 lpm	NA
	Head of Main pump	NA	45 m	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	Underground tank capacity	NA	25,000 ltrs	NA
	Draw-off connection	NA	Provided	NA
	Fire service inlet	NA	Provided	NA
	Access to tank	NA	Provided	NA
	Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA

01

NA	NA	NA	NA
NA	NA	NA	NA
NA	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the fire safety certificate issued vide letter no. F6/DFS/MS/EH/2022/SZ/20 dated 18/01/2022 under Rule 37 of the Delhi Fire Service Rules, 2010.

*ADO (B/W)*  
10/1/25

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

~~ADO (B/W)~~

DO (S/D)

*mm* 10/1/25

CHO (K/S)

13/01/2025

Director

14/1/25

Dr: FT letter in Duty for sign please  
16/1/25

~~Director (S/D)~~

*mu*

uploaded  
17/1/25