



FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/Metro/2026/NDZI/25

Dated: 13.02.2026

FIRE SAFETY CERTIFICATE

Certified that the **DMRC Shastri Park Depot, Delhi- 110053**, building comprising of Shastri Park Depot including, 04 Blocks of G+1 only (**DO Building, DCC, ETU & old Training building**) and 10 blocks of Ground only (**Extension of Work Shop cum inspection bay line & Pit Wheel lathes, canteen, stabling sed, P way building, Sub-station I & II, DCO Building**) owned/occupied by M/s Delhi Metro Corporation was issued FSC vide letter No. F.6/DFS/MS/Metro/2022/407 dated 15/09/2022. The premises was inspected by the officer concerned of this department on dated 12/01/2026 in the presence of Manager and observed that all the fire prevention and fire safety arrangements provided in the premises and found that the said premises having deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit occupancy class "**Industrial building (Except DMRC Simulator Building and Training Blocks G+3)**" effect from 13.02.2026 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on...13.02.2026.....at New Delhi by.


13/2/26

(Dr. S. K TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

To,

1. Sr. DGM/E&M, Metro Bhawan, Fire Brigade Lane, New Delhi 110001
2. Dy. General Manager/Elect/PD, 25, Ashoka Road, Near Patel Chowk Metro Station), Delhi- 110001

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. Construction of lift lobby or installation of Fire curtain in the lift shall be provided by the management within six months failing which Fire Safety Certificate should be treated null a& void.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/17

1. Name & address of the building : DMRC Shastri Park Depot, Delhi- 110053
2. Building is comprised of : Shastri Park Depot including, **04 Blocks of G+1 only** (DO Building, DCC, ETU & old Training building) and **10 blocks of Ground only** (Extension of Work Shop cum inspection bay line & Pit Wheel lathes, canteen, stabling sed, P way building, sub station I & II, DCO Building)
(Except DMRC Simulator Building and Training Block which are G+3)
3. Type of Occupancy : Industrial
4. Type of Case : Addition/Alteration
5. Details of Previous NOC letter : F.6/DFS/MS/Metro/2022/407 dated 15/09/2022
6. Fire Safety directive letter No. : F.6/DFS/MS/BP/2025/157 dated 08/05/2025
F.6/DFS/MS/BP/2025/371 dated 01/12/2025
7. Date of Inspection : 20/01/2026
8. Name of the Inspecting officers : ADO (Shd), Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Sayam Jain (Manager)
10. Year of Construction : 2007 & 2026
11. Applicant's letter No : DMRC/O&M/Fire/NOC/Line-1/2026/01/01
dated 07/01/2026 & DMRC/E/UD/DFS/CFUD-12/2025/L-4279 dated 01/12/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	Required	On Main Road	MR
	• Gate width	Required	7.21 mtr.	MR
	• Width of internal road	Main Road	06 mtr.	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	06 nos	DO bldg-2, DCC-1, ETU-2, Old Trg bldg-1	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	Required	DO bldg-1.75 m & 1.1 m, DCC-1.45 m, ETU-1.45 m x2 & Old Trg bldg—1.50 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 m	1.50 m, 02 m	MR
03	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilated	MR
05.	Fire Extinguishers			
	• Total numbers	136 nos.	Provided	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	Required	DO bldg-4, DCC-2, ETU-2, Old Trg bldg-2, IBL-5, PIT-2 & W.shop-5	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of main panel	Ground Floor	At Main gate	MR
	• Location of repeater panel	Required	DCC, Trg. Blk & DO bldg.	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter	N/A	DO bldg-7, DCC-3, ETU-1, Old Trg bldg-2, IBL-4, ASS-2, Canteen-2	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Work shop bldg.	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	Required	DO bldg-4, DCC-2, ETU-2, Old Trg bldg-2, IBL-6, PIT Wheel-2, W shop-5	MR
	• Hose box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	Required	73 no.	MR
	• Hose box	Required	73 no.	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	2280 LPM	2850 LPM	MR
	• Head of main pump	70 mm	70 mm	MR
	• Number of main pumps	02 no.	02 no.	N/A
	• Jockey pump out put	180 lpm	180 lpm	N/A
	• Jockey pump head	70 mtr	70 mtr	N/A
	• Standby pump out put	2280 LPM	2850 LPM	MR
	• Standby pump head	80 mm	80 mm	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	900 lpm	900 lpm	MR
	• Head of the pump	60 mtr	60 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 Ltrs	2,00,000 Ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity per Block	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	CO ₂ Panel flooding for HT & LT Panel	Provided	MR

Note:-DO- Director Operation building, DCC-Deport Control Center, ETU-Engineer Train Unit & DCO- Depot Contoral of Stores.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval and signature please.

Deepak Kumar
20/01/2016
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (TP/Shah.)

DO (ED) *[Signature]*

Pl. check & confirm occupancy on last F.S.C

Dy. CPO (NDZ) *[Signature]* 27/11/26

DO (ED) *[Signature]*

ADD (TP/Shah.)

pl. sir, corrected DFA put up for your approval

DY CPO (NDZ) *[Signature]* 31/2/26

Deepak Kumar
05/02/20

Principal Director *[Signature]* 19/02/26 *[Signature]* 07/2/26