

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DELHI FIRE SERVICE HEADQUARTERS
CONNAUGHT PLACE, NEW DELHI - 110001

PUBLIC NOTICE

General public is hereby informed that **NO PERMISSION IS REQUIRED** from Delhi Fire Service for:

1. Installation of new electricity connection / Increasing load of electricity connections / temporary connections.
2. Installation of security gates.
3. Fire safety measures in the pandals: The Section 26 of the Delhi Fire Service Act 2007 makes the fire prevention and fire safety measures in the pandals to be self regulatory.

Further, Delhi Fire Service does not levy any charges for providing following services.

1. Calling of Fire service for Fire Fighting / Rescue Operations.
2. Fire Fighting / Rescue Operations.
3. Issue of Fire / incident reports and corrections thereof. This can be downloaded from our website at http://dfs.delhigovt.nic.in/dfs2/r_publicSearch.asp?user=public.
4. Issue of Fire and life safety guidelines under rule 34 of Delhi Fire Service Rules 2010 for the buildings covered under Rule 27.
5. Issue of Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010 on compliance of Fire and life safety guidelines. The issued Fire Safety Certificates can be downloaded for free from our website at http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Centralized+Order.
6. Renewal of Fire Safety Certificates (Form J).
7. Submission of annual declaration (form K) regarding operability of Fire and life safety systems under the provisions of Rule 38.
8. On site Fire and evacuation drills, lecture and demonstrations.
9. Educational visit to the Fire stations.

Please note that:- No official of this department is authorized to Install / Refill Fire safety equipments and maintenance thereof. No agency / contractor is authorized / approved by this department for installation of Fire safety equipments at your premises. In case of any inconvenience the matter may be reported to nearest police station or vigilance department of Delhi Fire Service.

In case of emergency, Dial 101

Director
Delhi Fire Service

Give way to Fire engines. Know your escape routes for safe evacuation.

DIP/Shabdarthi/0653/16-17

03/6/16





GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

75
आजादी का
अमृत महोत्सव

No. F.6/DFS/HQ/2025/ 2188

Dated: 22/12/2025

To

1. Head Office, Tata Power - DDL, NDPL House, Hudson Lines, Kingsway Camp, Delhi - 110009.	2. Head Office, BSES, Rajdhani Power Ltd, BSES Bhawan, Nehru Place, New Delhi - 110019.	3. Chairman, NDMC, Palika Kendra Parliament Street, New Delhi - 110001.
--	--	---


Sub: No permission required for New Electricity Connection/ Increasing of Load of Electricity Connections /temporary Electricity Connections.

Sir,

With reference to subject cited matter, it is to inform you that this department released a public notice (copy enclosed) that No permission is required from Delhi Fire Service for installation of new electricity connection/ increasing load of electricity connections /temporary connections. It has been brought to the notice of this department that permission/ clearance from Delhi Fire Service is sought by electrical authorities for restoration /connection of electrical installation.

In view of above and in the light of above said public notice it is informed this department does not issue any NOC /permission letter for installation of electricity connection/ restoration etc.

Yours faithfully,


19/12/25
(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. P.A. to Principal Director
2. All Deputy Chief fire Officers
3. All Divisional Officers and Assistant Divisional Officers
4. ADO (M)- uploading on website of DFS.