



No. F6/DFS/MS/School/NDZ/2025/ 887

Dated: 19 / 12 / 2025

To,

Dr. R.S Baghal (Manager),
D. S Public School
Kh. No. 621, Sultanpur Extn.
New Delhi – 110030.

Subject: - Regarding grant of Fire Safety Certificate in r/o D.S Public School located at Kh. No. 621, Sultanpur Extn. New Delhi – 110030.

Sir,


This has a reference to your Outdoor Dairy No. 8189 dated 12/11/2025 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 08/12/2025 in the presence of Dr. R.S Baghal (Manager) and observed that school building comprised of Basement (Vacant), Ground plus three upper floors but school running on ground plus three upper floors only.

Following shortcomings were observed during time of inspection:

1. Fire Extinguisher, found empty.
2. First-Aid Hose reel provided but found not functional.
3. Fire pump of capacity 450 LPM provided but not functional.
4. Overhead water storage tank of capacity 5000 liters provided against requirement 10,000 liters.
5. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,


13/12/25
(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
o/c @

Copy to: -

1. The Dy. Director of Education, Govt. of NCT of New Delhi DISST. South Block – C, Defence Colony, New Delhi - 110024.