



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 53

Dated: 22/01/2025

FIRE SAFETY CERTIFICATE

Certified that the **D.T.E.A. Senior Secondary School** located at Laxmi Bai Nagar, New Delhi-110023 (School ID: 1719074) comprised of Ground Floor, 1st Floor & 2nd Floor only, owned/occupied by Delhi Tamil Education Association (Regd.), was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2021/842 dated 11/10/2021. The premise was re-inspected by the officer concerned of this department on dated 10/01/2025 in the presence of Sh. Parveen Bari (Offg. In-charge) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular No. 262-362 dated 17/01/2005 and that the building is fit for occupancy class "**Educational**" (Group B) with effect from 22/01/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/01/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Principal, D.T.E.A. Senior Secondary School located at Laxmi Bai Nagar, New Delhi-110023 (School ID: 1719074)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, prior to its expiry.

INSPECTION REPORT			
1.	Name & address of the building	D.T.E.A. Senior Secondary School located at Laxmi Bai Nagar, New Delhi-110023 (School ID-1719074)	
2.	Type of Occupancy	Educational (Group-B)	
3.	Building Comprised of	Ground + two upper floors only.	
4.	Type of Case	Renewal	
5.	Details of previous NOC No.	F.6/DFS/MS/School/SZ/2021/842 Dt. 11/10/2021	
6.	Fire Safety directives Letter No.	DOE Circular No. 262-362 dated 17/01/2005	
7.	Date of inspection	10/01/2025	
8.	Name of the Inspecting Officer	ADO (SJ)	
9.	Name and designation of Officer from the building side	Sh. Parveen Bari (Offg. In-charge)	
10.	Year of Construction	1960	
11.	Applicant's letter No.	Form 'J' received through outdoor diary No. 10935 dated 02/01/2025	
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Remarks MR/NMR
1.	Access of building	Provided at site	MR
	• Road width	06 mtr	MR
	• Gate width	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-
2.	Number, width, Type & Arrangements of exits		
	a. Number of staircases		MR
	• Upper floors	02 Nos	05 Nos
	• Basements	-NA-	-NA-
	b. Width of staircases		MR
	• Upper floors	1.50 mtr	2m, 1.50m, 1.33m & 0.75m x 2
	• Basements	-NA-	-NA-
	c. Protection of exits		-NA-
	• Fire check door	-NA-	-NA-
	• Pressurization	-NA-	-NA-
	d. No of continuous staircase to terrace	One	Three
	e. Width of Corridor	1.50m	1.50m
	f. Door Size	1.0m	1.0m
3.	Compartmentation		-NA-
	• Fire check door	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-
	• Water Curtain	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-
4.	Smoke Managements System		-NA-
	• Basements	-NA-	-NA-
	• Upper floors	-NA-	-NA-
5.	Fire Extinguishers		MR
	• Total numbers	25 Nos	30 Nos
	• Types	ABC/CO ₂	ABC & CO ₂
	• ISI marking	ISI Marked	Provided
6.	First-Aid Hose Reels		MR
	• Total numbers on each floor	01 No	01 No
	• Length of hose reel hose	30m	30m
	• Nozzle diameter	5mm	5mm

7.	Automatic fire detection and alarming system			
	• Type of detector	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	-NA-	-NA-	-NA-
	• Upper Floor	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down- comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	28m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw of connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000 Ltr	10,000 Ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	➤ Pressurization of lift lobby	-NA-	-NA-	-NA-
	➤ Communication in lift Car	-NA-	-NA-	-NA-
	➤ Fireman's Grounding Switch	-NA-	-NA-	-NA-
	➤ Lift Signage	-NA-	-NA-	-NA-
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

19.	Fire Control Room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/SZ/2021/842 dated 11/10/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval and signature please.

S. Kumar
15.01.25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)
[Signature] 15/01/25
CEO (KWS)
[Signature] 15/01/2025
Director (M)
[Signature]
ADDO (SJ)

Sir, FT letter is put up for your sig. pr

[Signature]
[Signature]
[Signature]
S. Kumar
21/01/25