



No. F6/DFS/MS/EH/SZ/2026/ 248

Dated: 25/03/2026



FIRE SAFETY CERTIFICATE

Certified that the M/s **Eat Food Lounge** DLF Promenade Mall located at Plot No. 3, Nelson Mandela Marg, Vasant Kunj, New Delhi – 110070 in a building comprised of Two-tier Basements, Lower Ground floor and Upper Ground floor and First floor & Projection room owned/occupied by DLF Promenade Mall was issued FSC vide letter No. F6/DFS/MS/EH/2023/SZ/163 dated 25/05/2023. The premises was re-inspected by the officer concerned of this department on 13/03/2026 in presence of Mr. Arun (Fire Safety Officer) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in the accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Group - D “Assembly Building” (**Food Lounge at first floor only**) with effect from 25/03/2026 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 25/03/2026 at New Delhi by.

24/3/26.

A.K Mailk
Dy. Chief Fire Officer
Delhi Fire Service
o/c (w)

Copy to :-

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi - 110016 (Ref. MHA Application No. 2026030302294 dated 03/03/2026)
2. The Manager, **Eat Food Lounge** DLF Promenade Mall located at Plot No. 3, Nelson Mandela Marg, Vasant Kunj, New Delhi – 110070.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/10

INSPECTION REPORT

1	Name & address of the building	M/s Eat Food Lounge, DLF Promenade Mall, Plot No. 3, Nelson Mandela Marg, Vasant Kunj, New Delhi - 110070.			
2	Building is comprised of	Two tier Basements, ground plus two floors.			
3	Type of occupancy	Assembly Building Group - D (Restaurant)			
4	Type of case	Renewal Case			
5	Details of previous FSC	F6/DFS/MS/EH/2023/SZ/163 dated 25/05/2023			
6	Fire safety directives letter no.	FSC No. FSC No. F6/DFS/MS/Mall/2025/SZ/483 dated 15/09/2025 of Promenade Mall			
7	Date of inspection	13/03/2026			
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/M. Road			
9	Name of the designation of officer from the building side	Mr. Arun (Fire Safety Officer)			
10	Year of construction	2005	Eat Food Lounge running at first floor ✓		
11	Applicant's letter no.	MHA Application No. 2026030302294 dated 03/03/2026			
S. No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR	
1.	Access to Building:				
	A	Road width	Restaurant within Mall	As above	MR
	B	Gate width		As above	N/A
	C	Width of internal road		As above	N/A
2.	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases	Provided & Maintained by DLF Promenade Mall		
	a	Upper floor	02 nos.	As above	MR
	b	Basement	N/A	As above	MR
	B	Width of staircases	Provided & Maintained by DLF Promenade Mall		
	a	Upper floor	1.50 meters	15 x 1.50 meters & 4 x 1.10-1.48	MR
	b	Basement	N/A	As above	N/A
	C	Protection of exits	Provided & Maintained by DLF Promenade Mall		
	a	Fire check door	Required	As above	MR
	b	Pressurization	N/A	As above	N/A
	D	No. of continuous staircases to terrace	Required	As above	MR
	E	Width of corridor	N/A	N/A	N/A
	F	Door size	Required	Provided	MR
3.	Compartmentation: Provided & Maintained by DLF Promenade Mall				
	A	Fire check door	Required	As above	MR
	B	Sealing of electrical shafts	Required	As above	MR
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4.	Smoke Management System: Provided & Maintained by DLF Promenade Mall				
	A	Basement	N/A	As above	N/A
	B	Upper floor	Required	Mechanical Ventilation	MR

N/11

5.	Fire Extinguisher:				
	A	Total numbers	12 nos.	24 nos.	MR
	B	Types	ISI Marked	ABC & CO ₂	MR
	C	ISI marking		Provided	MR
6	First-Aid-Hose Reel: Provided & Maintained by DLF Promenade Mall				
	A	Total numbers of each floor	Hose Reel	One in Restaurant	MR
	B	Length of hose reel hose		30 meters.	MR
	C	Nozzle diameter		05 mm	MR
7	Automatic Fire Detection and Alarming System: Provided & Maintained by DLF Promenade Mall				
	A	Type of detectors	N/A	Smoke/Heat	N/A
	B	Location of main panel	N/A	As above	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	As above	N/A
	E	Hooter's Location	N/A	As above	N/A
8	MOEFA:		Required	As above	MR
9	Public Address System:		N/A	As above	N/A
10	Automatic Sprinkler System: Provided & Maintained by DLF Promenade Mall				
	A	Basement	N/A	As above	N/A
	B	Upper floor	N/A	Provided in rest.	N/A
	C	Sprinkler above false ceiling	N/A	As above	N/A
11	Internal Hydrants: Provided & Maintained by DLF Promenade Mall				
	A	Size of riser/down-comer	Required	As above	MR
	B	Number of hydrants per floor	Required	As above	MR
	C	Hose box	Required	As above	MR
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	As above	N/A
	B	Hose box	N/A	As above	N/A
13	Pumping Arrangements: Provided & Maintained by DLF Promenade Mall				
1	Ground level				
	A	Discharge of main pump	N/A	4500 LPM	N/A
	B	Head of main pump	N/A	70 m	N/A
	C	Number of main pumps	N/A	02 nos.	N/A
	D	Jockey pump out put	N/A	450 LPM	N/A
	E	Jockey pump head	N/A	70 m	N/A
	F	Standby pump out put	N/A	4500 LPM	N/A
	G	Standby pump head	N/A	70 m	N/A
	H	Auto starting /manual stopping	N/A	As above	N/A
2	Terrace Level Provided & Maintained by DLF Promenade Mall				
	A	Discharge of pump each block	900 LPM	As above	MR
	B	Head of the pump	Required	As above	MR
	C	Power supply	Required	As above	MR
	D	Auto starting of pump	Required	As above	MR

W

14 Captive Water Storage for Fire Fighting: Provided & Maintained by DLF Promenade Mall				
A	Underground tank capacity	4,60,000 liters	As above	MR
B	Draw-off connection	Required	As above	MR
C	Fire service inlet	Required	As above	MR
D	Access to tank	Required	As above	MR
E	Overhead tank capacity	30,000 liters	As above	MR ✓
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts: Provided & Maintained by DLF Promenade Mall				
A	Pressurization of lift shaft	N/A	As above	N/A
		N/A	As above	N/A
B	Pressurization of lift lobby	N/A	As above	N/A
C	Communication in lift car	N/A	As above	N/A
D	Firemen's grounding switch	N/A	As above	N/A
E	Lift signage	N/A	As above	N/A
17 Standby Power Supply:		Required	Provided (DG Set)	MR
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room: Provided & Maintained by DLF Promenade Mall				
A	Detector system panel	N/A	As above	N/A
B	Flow switch panel	N/A	As above	N/A
C	PA system panel	N/A	As above	N/A
D	Battery backup	N/A	As above	N/A
E	Building floor plans	N/A	As above	N/A
20 Special Fire Protection systems for protection of special Risks, if any:				

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F6/DFS/MS/EH/2023/SZ/163 dated 25/05/2023, renewal under Rule 37 of the Delhi Fire Service rules 2010, is recommended to be renewed.

Note: - Last disposal date of the case is 01.04.2026

Signature of the Inspecting Office
 Name: Yashwant Singh Meena
 Designation: ADO/Mathura Road

D.O/SD
 18/3/26
 Ravinder Singh

19/3/26
 A.K. MALIK

Principal Director

19/3/26
 A.K. MALIK

19/03/26