

c/28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/2025/ 134

Dated : 17.04.2025

**FIRE SAFETY CERTIFICATE**

Certified that EGO ( A Unit Bana Fashions N Food Pvt Ltd) located at 14, Omaxe Building, Jasola, New Delhi in a building comprised of 02 basement + ground +5 upper floors. was earlier granted FSC by this department to vide letter No.F6/DFS/MS/EH/SZ/2022/246 dated 05/09/2022. Now, the restaurant premises was re-inspected by the officers concerned of this department on 09/04/2025 in the presence of Manager and found that the said restaurant premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant premises is fit for occupancy class **Assembly occupancy (Group D) "Restaurant at ground floor only"** and valid up to the period of three year from the date of issue in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 17/04/2025 at New Delhi by.

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi. : to kindly ensure the occupancy and deviation in construction if any.
2. The Dy. Commissioner of Police (Lic) , Ist floor, PS Defence Colony , New Delhi Online ID no. 2025031903990 dated 21/03/25.
3. The Manager, EGO ( A Unit Bana Fashions N Food Pvt Ltd) located at 14, Omaxe Buildingjg, Jasola, New Delhi.

**Conditions for the validity of fire safety certificate**

1. This FSC is valid for restaurant at ground only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Basement shall be used strictly as per BBL concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape such as exits, corridor, etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable for interior decoration shall strictly be prohibited.

155  
INSPECTION REPORT

1. Name & address of the building EGO ( A Unit Bana Fashions N Food Pvt Ltd)  
located at 14, Omaxe Building, Jasola, New Delhi
2. Type of occupancy:- Assembly occupancy - Group-D 02 B+G+5 upper floor  
**Restaurant running at ground floor only**
3. Type of case:- Renewal
4. Details of previous FSC:- No.F6/DFS/MS/EH/SZ/2022/246 dated 05/09/2022
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/04/25
7. Name of the inspecting officer:- Sh. Ravinder Singh, ADO (CC)
8. Name & designation of officer  
From the building side:- Manager
9. Year of construction:- 2010
10. Applicant's letter No:- ID no. 2025031903990 dated 21/03/25.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per N-1	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06	09 mtrs.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase	Restaurant running at Ground floor		
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 x 1.5 mtr	provided	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>	Provided and maintained by building management		
	1) Total numbers	06 Nos.	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>	Provided and maintained by building management		
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR

	3) Nozzle diameter	05 mm	05 mm	
7.	<b>Automatic Fire Detection &amp; Alarming System:</b>	Provided and maintained by building management		
	1) Type of detectors ( smoke )	Required	Provided	MR
	2) Location of main panel	ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>	Provided and maintained by building management		
	1) Size of riser/down-comer	100mm	100mm	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>	Provided and maintained by building management		
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	2850 lpm	N/A
	b) Head of main pump	N/A	70 mtrs.	N/A
	c) Number of main pump	N/A	02 nos.	N/A
	d) Jockey pump output	N/A	180 lpm	N/A
	e) Jockey pump head	N/A	70 mtrs.	N/A
	f) Stand by pump output	N/A	2850 lpm	N/A
	g) Stand by pump head	N/A	70 mtrs.	N/A
	h) Auto starting/Manual stopping	N/A	provided	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	900 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for Fire Fighting</b>	Provided and maintained by building management		
	1) Under ground tank capacity	N/A	1,50,000 ltr.	N/A
	a) Draw-off connection	N/A	Provided	N/A
	b) Fire service inlet	N/A	Provided	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 ltr.	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A

	Refuge Area	Provided	MR
	Total area location	N/A	N/A
		N/A	N/A
19.	<b>Fire Control Room</b>		N/A
	a) Detector system panel	N/A	N/A
	b) Flow switch panel	N/A	N/A
	c) PA system panel	N/A	N/A
	d) Battery backup	N/A	N/A
	e) Building floor plan	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>	N/A	NA

The fire protection systems provided in the restaurant premises were randomly tested, checked and found functional at the time of inspection.



In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No.F6/DFS/MS/EH/SZ/2022/246 dated 05/09/2022, under rule 35(6). Accordingly, letter is prepared and put up for kind perusal and signature and approval please.

Signature of the Inspecting Officer




Name :- Ravinder Singh  
Designation :- ADO (CC)

Dur Fairs  15/4/25


CFO (MS)  15/4/2025  
Director 



As approved, Fri put up for kind perusal and signature of perusal

Director 

 16/4/25

Uploaded  17/4/25