



e106

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/EH/2026/NDZ/116

Dated: 06/02/2026

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Narson Foods Pvt Ltd. (Zaika Bazar) located at 6, Parmesh Complex II, Karkardooma Community Centre, Delhi-110092. The building is comprised of Ground plus two upper floor only owned/occupied by M/s Narson Foods Pvt Ltd. was issued FSC vide letter F.6/DFS/MS/EH/2023/NDZ/32 dated. 27/01/2023. The premises was re-inspected by the officer concerned of this department on dated 20/1/2026 in the presence of Sh. Raj Nath Bhatt, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises and found that the said premises having deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit occupancy class "Assembly" Group D with effect from 06/02/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Conditions mentioned below.

Issued on 06/02/2026 at New Delhi by.



(Dr. S. K TOMAR)

BY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. The Owner/Occupier, M/s Narson Foods Pvt Ltd. (Zaika Bazar) located at 6, Parmesh Complex II, Karkardooma Community Centre, Delhi-110092.

MCD ID No. 2026010800241

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : M/s Narsion Foods Pvt Ltd. (Zaika Bazar)  
 6, Parmesh Complex II, Karkardooma Community Centre, Delhi-110092
2. Building is comprised of : Ground plus two upper floors only
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/2023/NDZ/32 dated 27/01/2023
6. Fire Safety directive letter No : Old requirements letter dated 24/12/2004
7. Date of Inspection : 20/01/2026
8. Name of the Inspecting officers : Deepak Kumar, ADO (TP/Shd.)
9. Name and designation of Officer from the building side : Sh. Raj Nath Bhatt, Manager
10. Year of Construction : 2002
11. Applicant's letter No : 206010800241 dated 08/01/2006

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirements Per letter dated 24/12/2004	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	N/A	30 mtr	MR old case
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	03 nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	02 m	1.10 m, 0.90 m & 0.70 m	MR old case
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	02 mtr.	MR
	f. Door Size	N/A	01 m (GF) & 0.80m, 0.80 m (FF) x 03	MR (old case)
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural ventilation	MR
05	Fire Extinguishers.			
	• Total numbers	04nos.	06nos.	MR
	• types	ABC/CO <sub>2</sub>	ABC/CO <sub>2</sub>	MR
	• ISI marking	Required	Provided	MR

06	First-aid-Hose Reels			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided 1st floor only	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-corer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	01 no	N/A
	• Hose Box	N/A	01 no	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main Pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby pump out put	N/A	N/A	N/A
	➢ Standby pump Head	N/A	N/A	N/A
	➢ Auto Starting /Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➢ Discharge of pump	450 lpm	450 lpm	MR
	➢ Head of the Pump	40 m	40 m	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 ltrs	6,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any.	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The earlier shortcomings issued vide letter no. F 6/DFS/MS/NDZ/2025EH/459 dated 02/12/2025 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter no. F 6/DFS/MS/EH/2023/NDZ/32 dated 27/01/2023 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Deepak*  
22/01/2026.

Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- A.D.O (TP/Shah)

DO(FD)

*[Signature]*  
22/1/26

Dy. CFO (NDZ)

*[Signature]*  
23/1/26

Principal Director

*My. Cfo to Room.*

*My. Cfo (NDZ)*

*[Signature]*  
24/01/26

*[Signature]*  
27/1/26

ADCT.P.

Sir, F.T. letter is put up for your kind signature pl.

*Deepak*  
05/02/2026

Dy CFO (NDZ)

*[Signature]*  
01/2/26

ms

*[Signature]*  
06/2/26