



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/EH/2026/NDZ/ 120

Dated: 10/02/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Jubilant Food Work Ltd. (Domino's Pizza) at Ground Floor, Shop No. G-40, Vikas Cine Mall, CBD Shahdara, Delhi-110032 is running at Ground floor only owned/occupied by M/s Jubilant Food Work Ltd. was issued FSC vide letter No. F.6/DFS/MS/EH/2022/NDZ/152 dated 01/06/2022. The premises was re-inspected by the officer concerned of this department on dated 27/01/2026 in the presence of Sh. Kamlesh Goswami, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises and found that the said premises having deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit occupancy class "Assembly" Group D (Ground floor only) with effect from 10/02/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Conditions Mentioned Below.

Issued on.....10/02/2026.....at New Delhi by.


3/2/26

(Dr. S. K TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to -

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. Sh. Yunus Khan, M/s Jubilant Food Work Ltd. (Domino's Pizza) at Ground Floor, Shop No G-40, Vikas Cine Mall, CBD Shahdara, Delhi-110032

MCD ID No. 2026011500536

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The FSC is valid for Ground floor only.

N/9.

1. Name & Address of the building : M/s Jubilant Food Work Ltd. (Domino's Pizza)
at Ground Floor, Shop No G-40, Vikas Cine Mall, CBD Shahdara, Delhi-110032.
2. Building is comprised of : 03 Basement, Ground + 04 upper floors
But restaurant is running ground floor only
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/EH/2022/NDZ/152 dt. 01/06/2022
6. Fire safety directive letter no. : NBC Part IV
7. Date of Inspection : 27/01/2026.
8. Name of the Inspecting officer : Deepak Kumar, A.DO. (TP/Shah.)
9. Name and designation of Officer from the building side : Sh. Kamlesh Goswami (Manager)
10. Year of Construction : 2006.
11. Applicant's letter No. : 2026011500536 dated 16/01/2026

S N	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirement	Provided at Site	Remark
1	Access to building			
	• Road width	06 m	39 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5 m x 02	1.5 m x 02	MR
	h. Door Size			
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	04 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

2.

		Provided in the Mall near restaurant		
6	First-aid-Hose Reels.	01 Nos	01 Nos	MR
	Total numbers of each floor	30 m	30 m	MR
	• Length of hose reel hose	05 mm	05 mm	MR
	• Nozzle diameter			
7	Automatic fire detection and alarming system.-	Provided in the Mall		
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	N/A	N/A	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System -	Provided in the Mall		
	• Basement	N/A	Provided	N/A
	• upper floor	N/A	Provided	N/A
	• sprinkler above false ceiling	N/A	Provided	N/A
11	Internal Hydrants	Provided in the Mall near restaurant		
	• size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	01 Nos.	01 Nos.	MR
	• Hose Box	01 Nos.	01 Nos.	MR
12	Yard Hydrants.	Provided in the Mall		
	• Total number of hydrants	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
13	Pumping Arrangements.	Provided in the Mall		
	• Ground Level			
	➤ Discharge of main Pump	2850 Lpm	2850 Lpm	MR
	➤ Head of Main Pump	70 m	70 m	MR
	➤ Number of main pumps	2 Nos.	2 Nos.	MR
	➤ Jockey pump out put	180 Lpm	2 No of 180 Lpm	MR
	➤ Jockey pump head	70 m	70 m	MR
	➤ Standby pump out put	2850 Lpm	2850 Lpm	MR
	➤ Standby pump Head	70 m	70 m	MR
	➤ Auto Starting /Manual stopping	Required	Auto	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	450 lpm	450 lpm	N/A
	➤ Head of the Pump	40 m	40 m	N/A
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	Provided in the Mall		
	• Underground tank capacity	N/A	2,00,000 Ltrs	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000Ltrs	25,000Ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any.	N/A	N/A	N/A

The Fire protection system provided in the building were tested and checked and found functional at the time of Inspection. The earlier shortcomings issued vide letter no. F.6/DFS/MS/EH/2025/SZ/220 dated 19/05/2025 has been rectified now.

Keeping in view, the deemed compliance of the minimum standards on Fire prevention and Fire safety measures as required under the rule. The Fire safety Certificate issued vide Letter No. F.6/DFS/MS/EH/2022/NDZ/152 dated 01/06/2022 renewal under Rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Last Date 15/02/2026

Deepak
28/01/2026

Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : A.D.O. (TP/SHD)

DO(EH) - out of station.

DCFO (NDZ) - *[Signature]*
29/1/26

Principal Director

By. CFO to *[Signature]*

By. CFO (NDZ)

[Signature]
29/01/26

[Signature]
30/1/26

Adol. Shet.
Sir, F.S. letter is put up for your signature pl.

DYCFD (NDZ)

[Signature]
2/2/26

MS

Deepak
09/02/2026