



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 515

Dated: 29/10/2025

To,

Mr. Anita Asija,  
M/s Energie Gym, GN-2 (Basement),  
Shivaji Enclave, Tagore Garden,  
New Delhi-110027.

**Sub:** Issue of FSC in r/o Energie Gym, GN-2 (Basement), Shivaji Enclave, Tagore Garden, New Delhi-110027.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 5077 dated 21.10.2025 on the subject cited above. The premise was inspected by the concerned nominated authority of this department on 14.10.2025, in presence of Mr. Anil Nanulato ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Alternate Exit staircase and door size is less than 1.5 m.
2. FCD is not provided in basement.
3. Smoke ventilation is not provided in the basement.
4. First Aid hose reel provided but not functional.
5. MOEFA is not provided.
6. Downcomer with hose box is not provided.
7. Terrace pump of 450 lpm is provided but not functional.
8. 3000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully



(S. K. Dua)

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service

