



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2025/SZ/ 98

Dated: 18/03/2025

FIRE SAFETY CERTIFICATE

Certified that M/s **Eniverse Hospitality LLP** located at Shop No. HS-11, Ground Floor, Kailash Colony Main Market, New Delhi-110048, comprised of ground plus two upper floors but the restaurant running at ground floor only, was issued fire safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2022/SZ/178 dated 15/06/2022 in the name of M/s Augment Hospitality LLP. The premises was re-inspected by the officer concerned of this department on dated 11/03/2025 in the presence of Sh. Vidur Kanodia (Owner) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and found that the said premises is fit for occupancy class "**Assembly Group-D**" (Restaurant at Ground Floor only) with effect from 18/03/2025 for a period upto **31/03/2028** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/03/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic.), First Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. online Id. No. **2025021902059** dated 19/02/2025)
2. Ms. Sakshi Kanodia, M/s Eniverse Hospitality LLP located at Shop No. HS-11, Ground Floor, Kailash Colony Main Market, New Delhi-110048

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry.

N-9

INSPECTION REPORT

1.	Name & address of the building	M/s Eniverse Hospitality LLP located at Shop No. HS-11, Ground Floor, Kailash Colony Main Market, New Delhi-110048		
2.	Type of Occupancy	Assembly "Group D" (Restaurant)		
3.	Building Comprised of	Ground plus 02 upper floors but Restaurant is running at ground floor only.		
4.	Type of Case	Renewal & change of name		
5.	Details of previous NOC No.	F6/DPS/MS/EH/2022/SZ/178 dated 15/06/2022 in the name of M/s Augment Hospitality LLP		
6.	Fire Safety directives Letter No.	Nil		
7.	Date of inspection	11/03/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Vidur Kanodia (Owner)		
10.	Year of Construction	1980		
11.	Applicant's letter No./Online Appn.	No. 2025021902059 dated 19/02/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Restaurant at ground floor only		
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50m x 2	1.50m each	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basement.	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	ISI marked	06 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI marking		Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Hose-reel	One	MR
	• Length of hose reel hose		30m	MR
	• Nozzle diameter		5mm	MR

JK

12-10

7.	Automatic fire detection and alarming system.			
	• Type of detector	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	One	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltr	Provided	MR
15	Exit signage	Required	Provided	MR
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

82

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/2022/SZ/178 dated 15/06/2022 in the name of M/s **Augment Hospitality LLP**, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended in the name of **Eniverse Hospitality LLP**.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
11/05/25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD) *[Signature]*
11/05/25

CEO (KOS)
[Signature]
15/05/2025

Director *[Signature]*
10/05/25

Sir, F.T letter is put up for your sig. pl

Director *[Signature]*
10/05/25

S. Kumar
17/05/25

uploaded
19/05/25

Ⓢ