



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75-6
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/2026/SZ/97

Dated: 02/10/2026

To,

The Principal,
Excel Public School (A Unit of Excel Foundation)
B – 381/9, Om Nagar, Badarpur, New Delhi – 110044.

Subject: - Regarding issuance of Fire Safety Certificate in r/o Excel Public School (A Unit of Excel Foundation) located at B – 381/9, Om Nagar, Badarpur, New Delhi – 110044.


Sir,

Please refer to your email dated 30/12/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 16/01/2026 in the presence of Mr. Manoj Kumar (Manager) and observed that the shortcoming has still not complied with as issued by this department vide letter no. F6/DFS/MS/School/SZ/2024/820 dated 11/12/2024 (copy overleaf).

In view of above, the application for issuance of Fire Safety Certificate is **rejected**. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Encl: as above


30/1/26
(A.K. MALIK)
Dy. Chief Fire Officer
Delhi Fire Service
01/11/26

Copy to: -

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block - C, Defence Colony, New Delhi - 110024.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/12
आप्लादीक
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 820

Dated: 11/12/2024

To

The Chairman,
Excel Public School (A Unit of Excel Foundation),
B-381/9, Om Nagar,
Badarpur New Delhi-44.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Excel Public School (A Unit of Excel Foundation) located at B-381/9, Om Nagar, Badarpur New Delhi-44..

Sir,

With reference to the letter bearing outdoor diary no. 9202 dated 19.11.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.12.2024 in the presence of Mr. Manoj Kumar (Manager) and it was observed that the school building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.
2. 2 nos. of staircases 1.50 meters width each has not been provided.
3. First aid hose reel has not been provided at each floor.
4. Fire pump of 450 LPM with head 40 m has not been provided.
5. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
6. Exit signage has not been adequate.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)
Director

Delhi Fire Service

06/12/24 e

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.