

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2025/SZ/130

Dated:-27/03/2025

To

Mr. Neeraj Bhatia (Dy. GM (Engg.)
NSC Limited, Beej Bhawan, Pusa Complex,
New Delhi 110012.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Farm Bhawan at 14-15,
Nehru Place, New Delhi

Sir,

This has reference to with letter no 16(8)/NSC-ENGG/FARM BHAWAN/FIRE
NOC/23-24 dated 17/02/2025 on the subject cited above. In this connection, it is to
inform you that the above mentioned premise was visited by the officer concerned of this
department on 19.03.2025 in the presence of Mr. Prem Kumar (Care taker) to verify the
fire safety measures installed in the building. During inspection, following points were
observed:

1. Fire Check door found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate
is rejected. The occupancy of the building/premises in absence of requisite fire safety
arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(APUL GARG)
DIRECTOR
DELHI FIRE SERVICE

9/11 e