



75
Azadi Ka
Amrit Mahotsav

C137

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/243

Dated: 17/04/2025

To

The Director of Education,
Govt. of NCT of Delhi,
Old Secretariat, New Delhi-110054

Sub: Inspection report in r/o Fouji Model School located at F-8, Gali No. 80, Mahavir Enclave, Part-3, New Delhi-110059

Sir,

This is with reference to the request letter received in this department outdoor diary No. 14608 dated 18.03.2025 for the renewal of FSC of Fouji Model School located at F-8, Gali No. 80, Mahavir Enclave, Part-3, New Delhi. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department from fire safety point of view on 04/04/2025 in the presence of Sh. Ankit Lochab (Manager). During course of inspection, the shortcomings observed are as below.

1. Terrace level fire pump was not on auto mode.
2. Exit signage found removed at some locations.
3. Third floor of the building being used for school activity despite submitting an undertaking dated 09.04.2021 regarding not to use third floor for school activities.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to take action as necessary for revoking the undertaking submitted in this department (copy enclosed). The occupancy of the building in the absence of valid Fire Safety Certificate shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(Virendra Singh)
Chief Fire Officer
Ph. 011-23414333

9/8/25

Copy to: -

1. The Manager, Fouji Model School located at F-8, Gali No. 80, Mahavir Enclave, Part-3, New Delhi-110059 <fmseducationsociety@gmail.com>