



No. F6/DFS/MS/Petrol/2025/SZ/ 587

Dated: 04/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that Filling Station - Cum Storage of Petroleum Class A & B at 7<sup>th</sup> Bn., D.A.P. PTS Complex, Malviya Nagar, New Delhi - 110017, Comprised of ground floor only was earlier issued FSC by this department vide letter no. F6/DFS/MS/Petrol/2020/SZ/497 dated 26/11/2020. Now, the premise was re-inspected by the officer concerned of this department on 16/10/2025 in the presence of Mr. Vikash (A.S.I.) and found that the filling station has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Group - J "Hazardous" with effect from 04/11/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/11/2025 at New Delhi by.

(A.K. Malik)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The DCP 7<sup>th</sup> Bn. DAP, PTS Complex, Malviya Nagar, New Delhi - 110017

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

01.	Name & address of the building	Filling Station- Cum Storage of Petroleum Class A & B at 7 <sup>th</sup> Bn., D.A.P. PTS Complex, Malviya Nagar, New Delhi -			
02.	Building is comprised of	Ground floor only.			
03.	Type of occupancy	Hazardous Building (Group-J)			
04.	Type of case	Renewal			
05.	Details of previous FSC	F6/DFS/MS/Petrol/2020/SZ/497 dated 26/11/2020			
06.	Fire safety directives letter no.	Nil			
07.	Date of inspection	16.10.2025.			
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (BCP)			
09.	Name of the designation of officer from the building side	Mr. Vikash (A.S.I.)			
10.	Year of construction	Not Known			
11.	Applicant's letter no.	Outdoor dairy no. 6483 dated 26/09/2025			
S.No	Minimum standard of fire prevention and fire safety U/R 33	As per Old NOC	Provided at site	Remarks MR/NMR	
01.	<b>Access to Building:</b>				
	A	Road width	Required	06 mtrs	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A
02.	<b>Number, Width, Type and Arrangement of Exits:</b>				
	A	Number of staircases			
	a	Upper floor	N/A	N/A	N/A
	C	Basement	N/A	N/A	N/A
	B	Width of staircases			
	a	Upper floor	N/A	N/A	N/A
	C	Basement	N/A	N/A	N/A
	C	Protection of exits			
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	N/A	N/A	N/A
	E	Width of corridor	N/A	N/A	N/A
	F	Door size	N/A	N/A	N/A
03.	<b>Compartmentation:</b>				
	A	Fire check door	N/A	N/A	N/A
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
04.	<b>Smoke Management System:</b>				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
05.	<b>Fire Extinguishers</b>				
	A	Total numbers	ISI marked	11 nos	MR
	B	Types		ABC-06, CO <sub>2</sub> -02, & Foam type-03	MR
	C	ISI marking		Provided	MR
06.	<b>First-Aid-Hose Reel:</b>				
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A

<b>07. Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooter's Location	N/A	N/A	N/A
<b>08. MOEFA:</b>		N/A	N/A	N/A
<b>09. Public Address System:</b>		N/A	N/A	N/A
<b>10. Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Ground Floors	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11. Internal Hydrants:</b>				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
<b>12. Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13. Pumping Arrangements:</b>				
<b>1</b> <b>Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2</b> <b>Terrace Level</b>				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A
<b>14. Captive water storage for firefighting.</b>				
	Underground tank capacity	N/A	N/A	N/A
	Draw of connection.	N/A	N/A	N/A
	Fire Service Inlet	N/A	N/A	N/A
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity	N/A	N/A	N/A
<b>15. Exit Signage:</b>		N/A	N/A	N/A
<b>16. Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17. Standby Power Supply:</b>		Required	Provided	MR

3

1112


Filling Station- Cum Storage of Petroleum Class A & B at 7<sup>th</sup> Bn., D.A.P. PTS Complex, Malviya Nagar, New Delhi

17.	Standby Power Supply:	N/A	N/A	N/A
18.	Refuge Area:			
	A Total area	N/A	N/A	N/A
	B Location	N/A	N/A	N/A
19.	Fire Control Room:			
	A Detector system panel	N/A	N/A	N/A
	B Flow switch panel	N/A	N/A	N/A
	C PA system panel	N/A	N/A	N/A
	D Battery backup	N/A	N/A	N/A
	E Building floor plans	N/A	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems such as fire extinguishers of different type and capacity Fir buckets filled with sand & water provided at suitable place in the retail outlet area were checked and found functional at the time of inspection.

"No SMOKING" sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.

Keeping in view the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/Petrol/2020/SZ/497 dated 26/11/2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended for approval.


  
17/10/2025

Signature of the Inspecting Officer  
Name: Yashwant Singh Meena  
Designation: - ADO/BCP

D.O/SD

  
17/10/25


~~Dy. CFS~~

  
22/10/25  
A.K. MALIK  
Principal Officer

Dy. Cfs to Inm.

~~Dy. CFS (SZ)~~

  
22/10/25

  
24/10/25  
A.K. MALIK

D.O/SD

  
28/10/25

~~ADO/BCP~~

P.T.O