



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-64
75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2026/181

Dated:- 03/03/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Food Sixteen (A Unit of Rinayra Hospitality), located at A-16, Upper Ground Floor, GT Road, Adarsh Nagar, Delhi-110033, in the building comprised of basement, stilt, upper ground floor & 03 upper floors but restaurant is running at upper ground floor only, owned/occupied by M/s Food Sixteen (A Unit of Rinayra Hospitality), was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/2023/316 dated 26/10/2023. The said premise was re-inspected by the officer concerned of this department on 26/02/2026 in the presence of Sh. Pulkit Aggarwal and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D "Assembly Building" (Restaurant) for upper ground floor only with effect from 03/03/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 03/03/2026 at New Delhi by.


S.K. Dua 02/03/26
Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002 :- in r/o online application id. 2026020301222 dated 03/02/2026.
2. The Authorized Signatory, M/s Food Sixteen (A Unit of Rinayra Hospitality), A-16, Upper Ground Floor, GT Road, Adarsh Nagar, Delhi-110033.

Conditions for the validity of fire safety certificate :-

1. This FSC is valid only for restaurant on upper ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form

N/12
INSPECTION REPORT

1. Name & address of the building : M/s Food Sixteen (A Unit of Rinayra Hospitality) located at A-16, Upper Ground Floor, Adarsh Nagar, Delhi-110033
2. Type of Occupancy : Assembly (Restaurant)
3. Composition of building : Basement, Stilt, Upper Ground & 03 Upper Floors but **restaurant is running at upper ground floor only**
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2023/316 dated 26/10/2023
6. Fire Safety directives Letter No. : Nil
7. Date of inspection : 26/02/2025
8. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
9. Name and designation of Officer from the building side : Sh. Pulkit Aggarwal
10. Year of Construction : 2015-16
11. Applicant's letter no. : 2026020301222 dated 03/02/2026

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	06 m	MR
	• Gate width	NA	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	02 m & 1.5 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2.0 m & 1.5 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	06 nos.	08 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR

P. A

6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	01 no.	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	Provided	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	UGF	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	UGF	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	Provided	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	UGF	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Ground Floor 	NA	Provided	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer 	Required	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01 no.	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01 no.	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level 	NA	NA	NA
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> Auto Staring/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	450 lpm	Provided	MR
	<ul style="list-style-type: none"> Head of the pump 	40 m	Provided	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> Draw off connection 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA

Q

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/EH/2023/316 dated 26/10/2023 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is prepared & put up for approval please.

~~DO (AW)~~ ~~ADP~~
27/02/2026

~~By CFO (WZ)~~

~~Pr. Director~~

By. CFO to Form.

~~ADP~~
27/02/26

~~ADP~~
27/02/26

~~By. CFO (WZ)~~

~~ADP~~
27/02/26
Aman Kumar Lathar
ADO (BW/RN)

F.T. letter is put-up for your signature M.

~~DO (WZ)~~

~~ADP~~
02/03/26

~~ADP~~
02/03/26
ADP (BW/RN)

~~F.P. WZ~~

~~ADP~~
03/03/26