



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No:F.6/DFS/MS/2026/WZ/247

Dated: 25/03/2026

To,

The Commissioner,  
Municipal Corporation of Delhi,  
S.P.M. Civic Centre, J.L. Nehru Marg  
New Delhi 110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Forever Restaurant & Party Hub (A unit of Forever Banquet and Hospitality Group) located at Property no. 20, Ground floor, Paschim Vihar extension New Delhi – 110063

Sir,

This has reference to online application received through MCD portal vide ID- 2026022702157 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 12/03/2026 to see the compliance of requisite fire safety measures. Sh. Manish was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Fire Check door found removed.
2. First aid hose reel nozzle found missing.
3. MOEFA found provided but not functional.
4. Terrace level pump not found in auto mode.
5. Overhead tank capacity found 10,000 ltrs against the required capacity of 20,000 ltrs.
6. Exit signage's found removed at some places.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(S.K. Dua)

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service

Copy to:-

1. M/s Forever Restaurant & Party Hub (A unit of Forever Banquet and Hospitality Group) located at Property no. 20, Ground floor, Paschim Vihar extension New Delhi – 110063
2. MCD Portal ID No. 2026022702157.