



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F6/DFS/MS/NZ/2026/ **365**

Dated: **12/08/2026**

To,

The SDM (Shalimarbagh),
District Central North,
DM Office Complex, Lawrence Road,
Rampura, Delhi - 110035

Sub: - Regarding initiation of legal action against in r/o M/s Fortis Hospital located at A-Block, Shalimar Bagh, New Delhi.

Sir,

This has reference to your letter no. F.No. SDM(SHB)/Fortis Hospt./2026/1677-1692 dated 21/07/2026 received through e mail id dated 22/07/2026 on the subject cited above. In this connection it is to inform you that the above said Hospital has been re-visited by the officer concerned of this department on 29/07/2026 in presence of Sh. Rajeev Kapur (Admin Head) to see the compliance of shortcomings issued by this department vide letter of even no. 274 dated 07/07/2026. During the course of inspection it has been observed that the following shortcomings are still not rectified.

1. Internal road of 6 m width for fire tender movement at under construction side area found blocked.
2. Unauthorized and unarranged parking found placed which can affect the fire tender movement in case of fire.

In view of the above, the FSC issued by this department vide online id no. 52026042302453 dated 08/06/2026 remain suspended till the compliance of above said shortcomings. The occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

This is for your kind information and further necessary action please.

Yours Faithfully

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Medical Superintendent, Fortis Hospital located at A Block, Shalimar Bagh, New Delhi.