

d58

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2025/ 555

Dated: 29/04 /2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Francis Girls Senior Secondary School, 17 Darya Ganj, New Delhi - 110002**, comprised of **ground one upper floor** was granted FSC by this department vide letter No. **F6/DFS/MS/08/2864 dated 13.10.2008**. The premises was re-inspected by the officer concerned of this department on 17.04.2025 in the presence of Mrs. Anusha Singh (In-charge) and found that the building is comprised of ground plus two upper floors but school is running at ground & 1<sup>st</sup> floor only. The building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 17.01.2005. The building is fit for occupancy **(Class-B) "Educational Building"**, **ground & first floor only** with effect from 29/04/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 29/04/2025 at New Delhi by

  
**(Atul Garg)**  
Director  
Delhi Fire Service  
Tel: 011-23414000  
o/c  
23/4

**Copy to:-**

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Francis Girls Senior Secondary School, 17 Darya Ganj, New Delhi - 110002.

**Conditions for the validity of Fire Safety Certificate**

1. This FSC is valid upto 1<sup>st</sup> floor (school) only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. Second floor found closed at the time of inspection.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1	Name and address of the building:	Francis Girls Senior Secondary School, 17 Darya Ganj, New Delhi - 110002.
2	Type of occupancy with details of floors:	Educational Building (Group-B) (Ground + 02 upper floors) But school is running at ground & 01 floor only
3	Type of case:	renewal
4	Details of previous FSC:	F6/DFS/MS/08/2864 dated 13.10.2008
5	Fire safety directives no.:	NA
6	Date of inspection:	17.04.2025
7	Name of the inspecting officer:	ADO (SPM)
8	Name and designation of the officer from the building side:	Mrs. Anusha Singh (In-charge)
9	Year of construction:	Old
10	Reference letter no.:	Outdoor diary no. 14807 dated 21.03.2025

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As per old NOC dated 13.10.2008	Provide at site	Remarks MR/NM R	
1	<b>Access to Building</b>				
	A	Road width	06 m	Provided	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>				
	A	<b>No. of Staircase:</b>			
		a) Upper floor	01 no.	03 nos.	MR
		b) Basements	NA	NA	NA
	B	<b>Width of the Staircase:</b>			
		a) Upper floor	01 no. - 1.50 mtr.	01 No.-1.40 mtr. & 01 No.-0.95 mtr. (ground to 1 <sup>st</sup> floor only) & 01 no.- 0.95 mtr	MR (being old case)
		b) Basements	NA	NA	NA
	C	<b>Protection of Exits</b>			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	01 no.	01 no.	MR
	F	Width of the corridor	NA	NA	NA
	E	Door size	1.0 mtr.	1.0 mtr.	MR
3	<b>Compartmentation:</b>				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	<b>Smoke management System:</b>				
	A	Basements	NA	NA	NA
	B	Upper floors	12 ACPH	Natural/ Exhaust fan	MR
5	<b>Fire extinguishers</b>				
	A	Total numbers	14 nos.	14 nos.	MR
	B	Types	Co2 & ABC	Co2 & ABC	MR
	C	ISI marking	Required	Provided	MR

<b>6</b>	<b>First Aid Hose reel</b>			
<b>A</b>	Total no. at each floor			
<b>B</b>	Length of Hose Reel	02 nos.	Provided	<b>MR</b>
<b>C</b>	Nozzle diameter	30 mtrs.	Provided	<b>MR</b>
<b>7</b>	<b>Automatic Fire Detection and Alarm System (ADAS)</b>			
<b>A</b>	Type of Detectors	NA	NA	NA
<b>B</b>	Location of main Panel	NA	NA	NA
<b>C</b>	Location of Repeater Panel	NA	NA	NA
<b>D</b>	Alternate power Source	NA	NA	NA
<b>E</b>	Hooter's location	NA	NA	NA
<b>8</b>	<b>MOEFA</b>			
<b>9</b>	<b>Public Address System</b>			
<b>10</b>	<b>Automatic Sprinkler System</b>			
<b>A</b>	Basement			
<b>B</b>	Upper Floor	NA	NA	NA
<b>C</b>	Sprinklers above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal hydrants</b>			
<b>A</b>	Size of the riser/down comer	NA	NA	NA
<b>B</b>	No. Of hydrants per floor	NA	NA	NA
<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants</b>			
<b>A</b>	Total no. of hydrants	NA	NA	NA
<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping arrangements</b>			
<b>A</b>	Ground Level			
	a) Discharge of main pump	NA	NA	NA
	b) Head of main pump	NA	NA	NA
	c) Number of main pump	NA	NA	NA
	d) Discharge of jockey pump	NA	NA	NA
	e) Head of jockey pump	NA	NA	NA
	f) Discharge of Standby pump	NA	NA	NA
	g) Head of Standby pump	NA	NA	NA
	h) Auto starting/ manual stopping	NA	NA	NA
<b>B</b>	Terrace Level			
	a) Discharge of terrace pump	225 LPM	Provided	<b>MR</b>
	b) Head of terrace pump	40 mtrs.	Provided	<b>MR</b>
	c) Alternate power supply	NA	NA	NA
	d) Auto starting of pump	Required	Provided	<b>MR</b>
<b>14</b>	<b>Captive Water Storage for Fire Fighting</b>			
<b>A</b>	Underground tank capacity	NA	NA	NA
<b>B</b>	Draw off connection	NA	NA	NA
<b>C</b>	Fire Service Inlet	NA	NA	NA
<b>E</b>	Access to tank	NA	NA	NA
<b>D</b>	Overhead tank capacity	3,000 ltrs	Provided	<b>MR</b> (being old case)
<b>15</b>	<b>Exit Signage</b>		Required	Provided
<b>16</b>	<b>Provision of lift</b>			
<b>A</b>	Pressurization of lift shaft	NA	NA	NA
<b>B</b>	Pressurization of lift lobby	NA	NA	NA
<b>C</b>	Communication in lift car	NA	NA	NA
<b>D</b>	Fireman switch	NA	NA	NA
<b>E</b>	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply</b>		NA	NA

18	Refuge Area		NA	NA	NA
	A	location	NA	NA	NA
	B	Total area	NA	NA	NA
19	Fire Control Room		NA	NA	NA
	A	Fire Detection System panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	P A system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any:				

The fire protection system provided in the school were tested, checked and random and found functional at the time of inspection.

**Note:** The school management has submitted an undertaking/affidavit stating school building is comprised of ground plus two upper floor but school is running at ground & first upper floor only. 2<sup>nd</sup> floor found closed at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety required as per rules FSC issued vide letter no. F6/DFS/MS/08/2864 dated 13.10.2008 renewal (school is running at ground & 1<sup>st</sup> upper floor only) under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Accordingly, DFA is put up for approval and signature please.

*Sumit Kumar*  
21/04/2025

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

~~DO (CD)~~

*Sumit Kumar*  
21/4/25

~~Dy. Commr (MS)~~

*Sumit Kumar*  
22/04/25

~~C.F.O.~~

*Sumit Kumar*  
23/4/2025

~~Director (DFS)~~

*Sumit Kumar*  
20/04/25

*Sumit Kumar*

F.T. letter is put up for signature, please.

~~Director (DFS)~~  
*Sumit Kumar*  
25/04/25

*Sumit Kumar*  
25/04/2025