



FIRE SAFETY CERTIFICATE

Certified that Friends Public School located at S – 531, School Block, Part – II, Shakarpur, Delhi – 110092, comprised of Ground plus two upper floor only owned/ occupied by Friends Public School have complied with the fire prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 12/04/2025 in the presence of Mrs. Sunita Sharma (Principal) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition in accordance with Circular No. 262-362 dated 17/01/2025 and that the school building is fit for occupancy class B “Educational Building” with effect from 23/04/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions, printed below.

Issued on 23/04/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education (GNCT), Old Secretariat, Delhi - 110054.
2. The Principal, Friends Public School located at S – 531, School Block, Part – II, Shakarpur, Delhi – 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. At the time of inspection second floor closed.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| 1 | Name & address of the building | Friends Public School located at S - 531, School Block, Part - II, Shakarpur, Delhi - 110092. | | | |
|------|---|---|------------------|---------------------------|----------------------|
| 2 | Building is comprised of | Ground plus two upper floors | | | |
| 3 | Type of occupancy | Educational Building | | | |
| 4 | Type of case | New | | | |
| 5 | Details of previous FSC | F6/MS/DFS/2007/143 dated 16/01/2007 (For Ground Floor only) | | | |
| 6 | Fire safety directives letter no. | Circular No. 262 - 362 dated 17/01/2005 | | | |
| 7 | Date of inspection | 12/04/2025 | | | |
| 8 | Name of the inspecting officers | Yashwant Singh Meena, ADO/ Laxmi Nagar | | | |
| 9 | Name of the designation of officer from the building side | Mrs. Sunita Sharma (Principal) | | | |
| 10 | Year of construction | 2006 | | | |
| 11 | Applicant's letter no. | Outdoor diary no. 14917 dated 24/03/2025 | | | |
| S.No | Minimum standard of fire prevention and fire safety U/R 33 | Circular Requirement | Provided at site | Remarks MR/NMR | |
| 1 | Access to Building: | | | | |
| | A | Road width | 6.0 meters. | 6.0 meters. | MR |
| | B | Gate width | N/A | N/A | N/A |
| | C | Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits: | | | | |
| | A | Number of staircases | | | |
| | a | Upper floor | 01 no. | 02 no. | MR |
| | b | Basement | N/A | N/A | N/A ✓ |
| | B | Width of staircases | | | |
| | a | Upper floor | 1.50 meters | 1.30 meter. & 1.50 meter. | MR (Old Accepted) |
| | b | Basement | N/A | N/A | N/A |
| | C | Protection of exits | | | |
| | a | Fire check door | N/A | N/A | N/A |
| | b | Pressurization | N/A | N/A | N/A |
| | D | No. of continuous staircases to terrace | 01 no. | 01 no. | MR |
| | E | Width of corridor | Required | Provided | MR |
| | F | Door size | 1.0 meter. | 1.0 meter. | MR |
| 3 | Compartmentation: | | | | |
| | A | Fire check door | N/A | N/A | N/A |
| | B | Sealing of electrical shafts | N/A | N/A | N/A |
| | C | Fire rating of shaft door | N/A | N/A | N/A |
| | D | Water curtain | N/A | N/A | N/A |
| | E | Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management System: | | | | |
| | A | Basement | N/A | N/A | N/A |
| | B | Upper floor | N/A | N/A | N/A |

⑥
DPA


| | | | | | |
|-----------|--|--------------------------------|-----------------------|-----------------------|-----|
| 5. | Fire Extinguisher: | | | | |
| | A | Total numbers | 08 nos. | 10 nos. | MR |
| | B | Types | CO ₂ & ABC | CO ₂ & ABC | MR |
| | C | ISI marking | ISI Marked | Provided | MR |
| 6 | First-Aid-Hose Reel: | | | | |
| | A | Total numbers of each floor | 01 no. | 01 no. | MR |
| | B | Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| | C | Nozzle diameter | 05 mm | 05 mm | MR |
| 7 | Automatic Fire Detection and Alarming System: | | | | |
| | A | Type of detectors | N/A | N/A | N/A |
| | B | Location of main panel | N/A | N/A | N/A |
| | C | Location of repeater panel | N/A | N/A | N/A |
| | D | Alternate source of power | N/A | N/A | N/A |
| | E | Hooters | N/A | N/A | N/A |
| 8 | MOEFA: | | N/A | N/A | N/A |
| 9 | Public Address System: | | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System: | | | | |
| | A | Basement | N/A | N/A | N/A |
| | B | Upper floor | N/A | N/A | N/A |
| | C | Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants: | | | | |
| | A | Size of riser/down-comer | N/A | N/A | N/A |
| | B | Number of hydrants per floor | N/A | N/A | N/A |
| | C | Hose box | N/A | N/A | N/A |
| 12 | Yard Hydrants: | | | | |
| | A | Total number of hydrants | N/A | N/A | N/A |
| | B | Hose box | N/A | N/A | N/A |
| 13 | Pumping Arrangements: | | | | |
| 1 | Ground level | | | | |
| | A | Discharge of main pump | N/A | N/A | N/A |
| | B | Head of main pump | N/A | N/A | N/A |
| | C | Number of main pumps | N/A | N/A | N/A |
| | D | Jockey pump out put | N/A | N/A | N/A |
| | E | Jockey pump head | N/A | N/A | N/A |
| | F | Standby pump out put | N/A | N/A | N/A |
| | G | Standby pump head | N/A | N/A | N/A |
| | H | Auto starting /manual stopping | N/A | N/A | N/A |
| | I | Pump house access | N/A | N/A | N/A |
| 2 | Terrace Level | | | | |
| | A | Discharge of pump | 450 LPM | 450 LPM | MR |
| | B | Head of the pump | 40 m | 40 m | MR |
| | C | Power supply | Required | Provided | MR |
| | D | Auto starting of pump | Required | Provided | MR |

6

| | | | | |
|--|------------------------------|---------------|---------------|-----|
| 14 Captive Water Storage for Fire Fighting: | | | | |
| A | Underground tank capacity | N/A | N/A | N/A |
| B | Draw-off connection | N/A | N/A | N/A |
| C | Fire service inlet | N/A | N/A | N/A |
| D | Access to tank | N/A | N/A | N/A |
| E | Overhead tank capacity | 10,000 liters | 10,000 liters | MR |
| 15 Exit Signage: | | Required | Provided | MR |
| 16 Provision of Lifts: | | | | |
| A | Pressurization of lift shaft | N/A | N/A | N/A |
| B | Pressurization of lift lobby | N/A | N/A | N/A |
| C | Communication in lift car | N/A | N/A | N/A |
| D | Firemen's grounding switch | N/A | N/A | N/A |
| E | Lift signage | N/A | N/A | N/A |
| 17 Standby Power Supply: | | N/A | N/A | N/A |
| 18 Refuge Area: | | | | |
| A | Total area | N/A | N/A | N/A |
| B | Location | N/A | N/A | N/A |
| 19 Fire Control Room: | | | | |
| A | Detector system panel | N/A | N/A | N/A |
| B | Flow switch panel | N/A | N/A | N/A |
| C | PA system panel | N/A | N/A | N/A |
| D | Battery backup | N/A | N/A | N/A |
| E | Building floor plans | N/A | N/A | N/A |
| 20 Special Fire Protection systems for protection of special Risks, if any: | | N/A | N/A | N/A |

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection. The shortcoming issued vide letter No. F6/DFS/MS/2009/1399 dated 19/05/2009 has been rectified.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 35 of Delhi Fire Service Rules 2010.


 15/4/2025
 Signature of the Inspecting Officer:
 Name: - Yashwant Singh Meena
 Designation: - ADO/Laxmi Naga

D.O/EAST

DFA Rhee

Dy C.F.O. (NDZ)

At present
16/4/25

KVP
16/04/25

C.F.O.

16/4/2025

Director

16/4/25

AD/LN

P.T.O