

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No. F6/DFS/MS/EH/2026/173

Dated: 25.02.2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Fujiya Restaurant, 12/48, Malcha Marg, Chanakyapuri, New Delhi - 110021 in a building comprises of Ground + One Upper Floor (But Restaurant is running at Ground floor only) was earlier issued FSC by this department vide letter No. F.6/DFS/MS/EH/2023/SZ/134 dated 27/04/2023. Now, the premises was re-inspected by the officer concerned of this department on 30/01/2026 in the presence of Sh. Rajmal Thakur (Manager) and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant is fit for occupancy class "Assembly Building (Restaurant) "Class - D" (Restaurant running at Ground floor only) with effect from 25/02.2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....25/02/2026.....at New Delhi by.


 (M. K. Chattopadhyay)
 Dy. Chief Fire Officer, FPW
 Delhi Fire Service
 94

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi. (MCD Online ID. 2026010500113 dated 15/01/2026)
2. The authorized signatory, M/s Fujiya Restaurant, 12/48, Malcha Marg, Chanakyapuri, New Delhi - 110021.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is only for restaurant at ground floor only.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building	M/s Fujiya Restaurant, 12/48, Malcha Marg, Chanakyapuri, New Delhi - 110021		
2.	Type of occupancy	Ground + One Upper Floor (But Restaurant is running at Ground floor only).		
3.	Type of case	Renewal		
4.	Details of previous FSC No.	F.6/DFS/MS/EH/2023/SZ/134 dated 27/04/2023		
5.	Fire safety directives No.-	Nil		
6.	Date of inspection: -	30/01/2026		
7.	Name of the inspecting officer: -	Sh. Kaushal Kishore, ADO(SJ)		
8.	Name & designation of officer from the building side: -	Sh. Rajmal Thakur (Manager)		
9.	Year of construction: -	1964		
10.	Applicant's letter No: -	Online application ID - 2026010500113 dated 15/01/2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per the old NOC/ Existing fire safety system	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	Accessible	09 mtrs.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircase			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	NA	01 no.	NA
	e. Width of corridor	NA	NA	NA
	f. Door size	02 m	1.0 m (2 nos.) each	MR (old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors/Restt. area	Required	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	05 nos.	05 nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI Marked	ISI Marked	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's Location	NA	NA	NA
		Required	Provided	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System			

10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose box per floor	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	Boosting	225 LPM	MR
	• Head of pump	NA	40 M	N/A
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	NA	NA	NA
	• Overhead tank capacity	4,000 Ltrs	4,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	NA	NA	NA
17.	Stand by Power Supply	Required	Provided (50 KVA DG set)	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	NA	NA	NA

N/24

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules 33 of DFS rules 2010, the FSC issued vide letter No. F.6/DFS/MS/EH/2023/SZ/134 dated 27/04/2023, renewal under rule 37 of Delhi Fire Service Rules 2010, is recommended, we may issue the FSC. The last date for deemed approval is 27/04/2023.

Accordingly, DFA is prepared and put up for kind perusal and approval please.

[Signature]
01/2/26

Signature of the Inspecting Officer
Name: - Kaushal Kishore
Designation: - ADO (SJ)

[Signature]
21/2/26

[Signature]

[Signature]
21/2/26
A.K. MALIK
Principal Director

My. cfo to Com.

[Signature]
My. cfo (S2)

[Signature]
14/02/26

[Signature]
DO (S1)
ADO (S5)
[Signature]
17/2/26
Ravinder Singh

ADD'S

ft letter is prepared & put up for kind approval please.

[Signature]
Dy. CFO/PPW

[Signature]
MS cell

[Signature]
20/2/26
ADO/SJ

[Signature]
25/2/26