

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/2025/EH/WZ/ 395

Dated: 24/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Ms/ Galore Hospitality LLP located at Shop No.3, N.W.A , Club Road, Punjabi Bagh, New Delhi-110026, comprised of basement + ground + 03 upper floors and restaurant is running at ground + 1<sup>st</sup> + 2<sup>nd</sup> floor (kitchen) has already been issued FSC by this department vide letter No. F.6/DFS/MS/WZ/EH/2022/313 dated 09.11.2022. The premises was re-inspected by the officer concerned of this department on 11.11.2025 in the presence of Mr. Vipin Kumar and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Assembly" Group-D with effect from 24/11/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/11/2025 at New Delhi by

  
24/11/25  
(S. K. Dua)

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service

Copy to: -

1. MCD Portal ID-2025103114511 dated 31.10.2025.
2. Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi-110027.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building	Ms/ Galore Hospitality LLP located at Shop No.3, N.W.A , Club Road, Punjabi Bagh, New Delhi-110026.
2. Type of Occupancy	Assembly (Group-D Eating House)
3. Comprised of building	Basement + Ground + 03 upper floors ( <b>Basement Sealed</b> )
4. Type of Case	Renewal (Restaurant is running at Ground + 1 <sup>st</sup> + 2 <sup>nd</sup> floor - <b>Kitchen</b> )
5. Details of Previous NOC	F.6/DFS/MS/WZ/EH/2022/313 dated 09.11.2022.
6. Fire Safety directives letter No	NBC Part-IV
7. Date of inspection	11.11.2025
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)
9. Name and designation of officers From the building side	Mr. Vipin Kumar
10. Year of Construction	1990-on MCD Portal
11. Applicant's letter No.	Online application No.2025103114511 dated 31.10.2025

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Rule 35 (6)	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12m	On main Road	MR
	• Gate width	5m	On main Road	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02nos.	01(G.F to terrace) 01 (G.F to 1 <sup>st</sup> )	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	Required	1x1m (G.F to terrace), 1x.96m (G.F to 1 <sup>st</sup> )	MR(old case)
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	-NA-	-NA-	-NA-
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	Required	G.F-1.06 & 0.83m F.F-0.87m	MR (old case)
3.	<b>Compartmentation</b>			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	08 nos.	Provided	MR
	b) Types	ABC/CO2	Provided	MR
	c) IS marking	ISI marked	Provided	MR
6.	<b>First-Aid Hose Reels</b>			

21/29

d) Fire  
e) Lift  
Standby p  
18. Refuge Ar

	a) Total numbers on each floor	01 nos.	Provided	MR
	b) Length of hose reel hose	30 nos.	Provided	MR
	c) Nozzle diameter	5 nos.	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	-NA-	-NA-	-NA-
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	Required	Provided	MR
	c) Sprinkler above false ceiling	Required	Provided	MR
<b>11.</b>	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	100m	Provided	MR
	b) Number of hydrants per floor	1nos.	Provided	MR
	c) Hose Box	1nos.	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	220 & 180lpm	Provided	MR
	➤ Head of the pump	30m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity			
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity			
		5,000 ltrs	Provided	MR
		Required	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>			
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-

	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/WZ/EH/2022/313 dated 09.11.2022 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]*  
 Signature of the Inspecting Officer  
 Name Ajay Kumar Sharma  
 Designation ADO(Wazirpur/MN)

~~DO (W)~~ *11/11/25*

~~AD (W)~~

*ADP*  
12/11/25

Principal Director

*my. Cfo to Comm.*

*my. Cfo (WZ)*

*[Signature]*  
12/11/25

~~ADO (WZ)~~

*ADP*  
19/11/25

FT letter is put up for (C) perusal and signature please.

*uplaced*

~~DFOC (WZ)~~  
F.P. wing

*ADP*  
24/11/25

*[Signature]*  
21/11/25