

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/WZ/GH/2025/ 23

Dated: 13/01/25

To,

Mr. Kuldeep Sethi,
House No.16, Street 7, 1st floor,
WEA, Karol Bagh,
New Delhi-110005.

Sub: Renewal of FSC in r/o M/s Guest House TJS Royale, located at 16, 16 WEA, Karol Bagh, New Delhi-110005.

Sir,

This is reference to online application no.2024123018528 dated 30.12.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **03.01.2025**, in presence of **Sh. Rakesh Chandra (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Co detector system not provided in basement.
2. Alternate staircase not provided in basement.
3. Hose reel not provided in basement.
4. Smoke ventilation not provided in basement.
5. FCD not provided in basement.
6. Terrace fire pumps were not found in auto mode.
7. Exit signage not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully



(Atul Garg)
DIRECTOR

Ph; 011-23414000



Copy To:-

1. MCD Portal Id- 2024123018528 dated 30.12.2024